

## APPENDIX B Estimation of the magnitude of radiant heat exchange

Part of the radiant energy being transmitted between adjacent wet surfaces is absorbed by the non-luminous medium through which it is being transmitted, namely, the moist air. This absorption comes about because of the water vapour present in the air.

The water surfaces would have an emissivity of 0,96 and may be considered as black bodies. The moist air has an equivalent emissivity which is dependent on the water vapour pressure, the total pressure, the temperature and the mean beam path length of the radiation. The moist air emissivity may be estimated from information presented in a number of texts (49,72,73), the basis of which is summarized in Figure B.1.

Three different geometries of direct-contact heat exchanger are considered. First, a fluted type cooling tower packing with a characteristic dimension of 20 mm (the wetted air passages may be considered as small ducts which change direction every 300 mm in a zigzag pattern; see Chapter 4). Second, parallel corrugated sheets spaced at 100 mm (this is a simple film-type packing with a large spacing). Third, an open spray chamber. These three configurations were chosen in an attempt to cover the widest range of possibilities.

The radiation interchange between the water surfaces and the moist air is given by:

$$\frac{q_r}{A} = \sigma \epsilon_a (T_{ws}^4 - T_a^4) \quad (B.1)$$




Figure B.1 Emissivity of air due to water vapour, valid for temperatures from 0 to 50 °C

which can be simplified(29) to:

$$\frac{q_r}{q_c} = h_r (t_{ws} - t_{db}) \quad (B.2)$$

$$\text{where } h_r = 2,3 \times 10^{-7} (273 + t_{ave})^3 \epsilon_a \quad (B.3)$$

$$\text{or } h_r = \epsilon_a \quad \text{for } t_{ave} = 25^\circ\text{C} \quad (B.4)$$

The form of Equation B.2 is identical to the normal convective heat transfer equation and the value of the radiative heat transfer coefficient,  $h_r$ , may be compared directly to the normal convective film coefficient,  $h_c$ . The values of these coefficients for the three configurations being considered have been calculated and are given in Table B.1.

The ratios of the radiative to convective heat transfer coefficient have values of 0,3; 2,8; and 0,4 per cent for the three different situations. The value of 2,8 per cent applies to the parallel corrugated plates; in fact, this configuration was chosen as an example in an attempt to maximize this ratio.

It may be stated that the value of this ratio will always be less than 3 per cent but normally around 0,5 per cent. Thus, the radiant transfer is small when compared to the convective heat transfer, which itself is usually small when compared to the total heat transfer.

Table B.1 Comparison of the convective and radiative heat transfer coefficients

	Flute type packing 20 mm Spacing	Corrugated sheets film type packing 100 mm Spacing	Open spray chamber
Water vapour partial pressure (kPa) (a)	3,2	3,2	3,2
Mean beam path length (m)	0,015 (b)	0,19 (c)	1,8 (d)
Moist air emissivity	0,01 (e)	0,05	0,
Radiative heat transfer coefficient ( $W/m^2 \text{ } ^\circ C$ ) (f)	0,06	0,31	1,20
Convective heat transfer coefficient ( $W/m^2 \text{ } ^\circ C$ )	20 (g)	11 (h)	300 (i)
Ratio $h_r/h_c$ (t)	0,3	2,8	0,4

Notes for Table B.1:

- For an air condition of 25 °C (saturated) and a barometric pressure of 100 kPa.
- Taken as 0,6 x diameter (see Mc Adams<sup>(49)</sup>).
- Taken as 1,8 x distance between planes (see Mc Adams<sup>(49)</sup>).
- Situation has been approximated to a spherical gas shape (see Bluhm<sup>(22)</sup>).
- Value has been extrapolated from published data (see Mc Adams<sup>(49)</sup>).
- Calculated at an average temperature of the air and the water surfaces of 25 °C. The value should be increased by 27 per cent or decreased by 23 per cent if the average temperature is 50 °C or 0 °C respectively.
- Approximated to flow inside pipes with 3 m/s air velocity (see Mc Adams<sup>(49)</sup>).
- Calculated for air velocity of 3 m/s and equivalent diameter of corrugations of 200 mm.
- Surprisingly high value due to the high relative velocity between the drop and the air stream (see Bluhm<sup>(22)</sup>).

APPENDIX C Listing of computer program used to  
simulate the performance of counterflow  
direct-contact water-air heat exchanger

```

10      : *****
20
30      : SIMULAYDR FOR DIRECT CONTACT COUNTERFLOW WATER-AIR HEAT EXCHANGER
31
33      : *****
40      : This listing has been stripped of all input/output and iteration
      : statements
50
60
70
90 Start: Main loop starts here
100
110
120      : *****
130      : Loop to calculate Tw_out and Mw_out from a knowledge of inlet air
      : and water conditions and flow rates
140
150      : ////////////////////////////////////////////////////
160      : Loop over N strips of tower
170
180      Pressure=Pressure_inlet-(I-1)/N*Delta_pressure ! Pressure at
      : each strip
190      GOSUB Spalding !Calculate Dmw/mass transfer!,Delta_q(heat transfer)
      : per strip
200      Ash_out=Ash_in+Dmw/Ma !apparent specific humidity, W, at outlet of
      : strip kg/kg
210      Enthalpy_out=Q_tot/Ma+Enthalpy_in ! Enthalpy at outlet of strip
220      Tdb_out=(Enthalpy_out-Ash_out*2381)/(1.895+Ash_out*1.84) ! Dry-
      : bulb at outlet of strip
230
240      ! Test for fogging
250      ! Calculate W(sat) at Tdb_out and compare with W_out
260
270      Esat=FHEsat(Tdb_out)
280      Ash_sat=.622*Esat/(Pressure-Esat)
290      IF Afog>0 THEN 310
300      IF Ash_out<Ash_sat THEN 600
310      Tdb_sat=Tdb_out !First guess for Tdb_out if saturated
320      E=Ash_out*Pressure/(.622+Ash_out) !Vapour pressure if no fog
330      Ei=Ash_out !First guess for saturated W at Tdb_sat
340      First_func=Ma*Enthalpy_in+Q_tot !****
350
360      : ////////////////////////////////////////////////////
370      : Loop for correct Twb,Tdb if fogging occurs
380
390      EB=.6105*EXP(17.27+Tdb_sat/(237.3+Tdb_sat)) !Saturated vapour
      : pressure at Tdb_sat
400      EBdash=EB*237.3+17.27/(237.3+Tdb_sat)*2
410      A7=.622*EB/(Pressure-EB) !Saturated W at Tdb_sat
420      H7=1.895+Tdb_sat*(2501+1.84*Tdb_sat)*A7 !Guess for Enthalpy_out
      : if fogging occurs
430      Sec_func=Ma*(H7+(Mfog+Dmw+Ma*(Ash_in-A7))*4.187*Tdb_sat
440      Sec_func=Sec_func-Mfog*4.187*Tdb_in
450      Dash_7=.622*Pressure*EBdash/(Pressure-EB)*2
460      F=Sec_func-First_func
470      Fdash=Ma*(1.895+2501+1.84*Tdb_sat)*Dash_7+1.84*Ash
480      Fdash=Fdash+(Mfog+Dmw+Ma*(Ash_in-A7))*4.187*Ma*4.187*Dash_7*Tdb_sat
490      IF ABS(F/Fdash)<1E-8 THEN 530
500      Z3=F/Fdash

```

```

510 Tdb_sat=Tdb_sat-23 Tdb_out if saturated
520 GO TO 390
530 D_afog=Daw+Mat*(Ash_in-A7)
540 Mfog=Mfag+D_afog !Mass of water vapour due to fogging
550 Tdb_out=Tdb_sat
560 Twb_out=Tdb_out
570 Ash_out=A7
580 Enthalpy_out=H7
590 GO TO 0k
600 !
610 ! End of loop for fogging
620 ! ////////////////////////////////////////////////////
630 GO SUB Wet_bulb !Calculates Twb out if no fogging
640 Ok: Sigma_out=Enthalpy_out-Ash_out+Cw*Twb_out
650 New_tw=(Cw*Mw+Tw(I)+D_tot)/(Mw+Daw+Cw)
660 Delta_tw=New_tw-Tw(I+1)
670 Tw(I+1)=New_tw
680 Mw_n=Mw+Daw !Water flow in next strip is actually IMLET
! water flow rate to this strip
690 ! Prepare for next strip
700 Tdb_in=Tdb_out
710 Twb_in=Twb_out
720 Ash_in=Ash_out
730 Enthalpy_in=Enthalpy_out
740 Sigma_in=Sigma_out
750 Q_tower=Q_tower+Q_tot!
760 Sum_sens=Sum_sens+Q_sens !Sum of sensible heat
770 Lat=Lambda*Dmw !Latent heat
780 Sum_lat=Sum_lat+Lat
790 Sum_fog=Sum_fog+Lambda*D_afog !Sum of heat due to fogging
800 !
810 ! F o r loop over N strips
820 ////////////////////////////////////////////////////
830 N !Return Mfag to air stream
840 Tw Mfag)*Tw(I)-Mfag*Tdb_out):Mw
850 Q_tot=Q_tower+Mfag*Cw*Tdb_out
860 IF (ABS(Tw(I)-TwI)<.0005) AND (ABS(Mwi-Mw)<.00005) THEN Print_result
! 0.005% error for flow
870 Tw_error=TwI-Tw(I) !Error in water temperature
880 Mw_error=Mwi-Mw !Error in water flow rate
890 Two_guess=Two_guess+Tw_error*Error_factor !New guess for Two
900 Mw_n=Mw_n+Mw_error !New guess for Mw_n
910 !
920 ! End of loop for Tw_out and Mw_out
930 ! ++++++
940 !
950 ! End of main program
960 #####
970 #####
980 #####
990 #####
1000 STOP

```

```

1810 ! *****
1820
1830 Spalding! Calculates water properties by method of Spalding
1840
1850 X=1 !For water temps in need INLET temp for this strip
1860 Tfilm=(Tw(X)+Tdb in)/2 !Temperature of film
1870 Ews=.6185*EXP(17.27*Tw(X))/(237.3+Tw(X)) !Saturated vapour
! pressure of water surface
1880 Esatd=.6185*EXP(17.27*Tw_in/(237.3+Tw_in)) !Saturated vapour
! pressure at wet bulb
1890 Eair=FNE(Tw in,Tdb in,Pressure) !Vapour pressure of air
1900 Efilm=.6185*EXP(17.27*ffilm/(237.3+Tffilm)) !Saturated vapour
! pressure at film temperature
1910 Ash_film=.622*Efilm/(Pressure-Efilm) !apparent specific humidity, W
1920 Ash_ws=.622*Ews/(Pressure-Ews)
1930 Sigma_ws=1.085*Tw(X)+(258)-2.387*Tw(X)*Ash_ws !Sigma heat water
! surface
1940 HnZo_ws=.622*Ews/(Pressure-.378*Ews) ! IN Kg H2O/Kg VAIR TSHws
1950 HnZo_inf=.622*Eair/(Pressure-.378*Eair) ! IN Kg H2O/Kg VAIR TSHinf
1960 Lambda=2581-2.587*Tw(X) !kJ/kg Latent heat
1970 Cp=(1.085+1.84*Ash_film)*(Pressure-Efilm)/(Pressure-.378*Efilm)
! IN kJ/Kg C Film Cp
1980 K=(2483+7.788*Tfilm)*10^(-5) !Film conductivity
1990 Diffusivity=1.676*10^(-7)*Tfilm+273.15)^1.694/Pressure
! m^2/SEC Film diffusivity
2000 Ro_film=(Pressure-.378*Efilm)/(1.287845*(273.15+Tffilm)) !kg vair/m^3
2010 Lewis=1/Cp+1888*Ro_film/Diffusivity(K)^2/3 !Lewis no
2020 B=LOG((1-HnZo_inf)/(1-HnZo_ws)) !Mass transfer driving force
2030 Dm=Hc_a/H*Lewis*B/Cp !Mass trans kg/s
2040 Q_sens=Hc_a/N*(Tw(X)-Tdb_in) !Sensible heat added
2050 Q_tot=Q_sens+Lambda*Dm !Total heat added
2060 RETURN
2070 ! *****
2080
2090 Wet_bulb! Calculates Twb_p_1 from Ash_n_1
2100
2110 Twb_guess=Twb_in
2120 E=FNE(Twb_guess,Tdb_out,Pressure)
2130 F=-.622*E
2140 F=Ash_out+F/(Pressure-E)
2150 Pdash=-.622*FRDe(Twb_guess,Tdb_out,Pressure)*Pressure
2160 Fdash=Pdash/(Pressure-E)*2
2170 Twb_out=Twb_guess-F/Fdash
2180 IF ABS(F/Fdash)<1.0E-4 THEN 1410
2190 Twb_guess=Twb_out
2200 GOTO 1320
2210 RETURN
2220 ! *****
2230
2240 DEF FNE(N,D,P) ! Vapour pressure kPa
2250 Esat=.6185*EXP(17.274/(237.3+N))
2260 E=(Esat*(1555.6-2.465*N+1.085*D)-P*(.085*(D-N))/(1555.6+.137*D-1.599*N
-Esat*.14*(D-N)/P)
2270 RETURN E
2280 FNE
2290
2300

```

```

1510 ! *****
1520 !
1530 DEF FNEsat(N) ! Saturated vapour pressure kPa
1540 Esat=.6105*EXP(17.27*N/(237.3+N))
1550 RETURN Esat
1560 FNEEND
1570 !
1580 ! *****
1590 !
1600 DEF FNDe(N,P) ! First derivative of vapour pressure
1610 Esat=.6105*EXP(17.27*N/(237.3+N))
1620 De=(371.4+.64*D-.4*N)*(Esat+.6+(371.4+.24*D-.6*N)*FNDesat(N)+.24*P)+(
Esat*(371.4+.24*D)-.6*N)-.24*(D-N)*P+.4
1630 De=De/(371.4+.64*D-.4*N)^2
1640 RETURN De
1650 FNEEND
1660 !
1670 ! *****
1680 !
1690 DEF FNDesat(N) ! First derivative of saturated vapour
pressure
1700 Desat=.6105*((1237.3+N)*17.27-17.27*N)/(237.3+N)^2)
1710 Desat=Desat*EXP(17.27*N/(237.3+N))
1720 RETURN Desat
1730 FNEEND
1740 !
1750 ! *****

```

**APPENDIX D. Heat exchanger test facility**


This appendix presents a published brochure giving details of the test facility.

(In support of this thesis it is noted that the author was responsible for the design, erection, commissioning of the centre as well as the present extensive programme of research carried out at this facility(3)).

# HEAT EXCHANGER TEST CENTRE



Chamber of Mines  
Research Organization



*Interior of test hall*



*Front cover — Nozzle bank for  
measuring airflow*

# THE NEW HEAT EXCHANGER TEST CENTRE

The commissioning of the Heat Exchanger Test Centre of the Chamber of Mines of South Africa Research Organization has provided the South African mining industry with an important research and testing centre. It is unique in that it is the largest facility of its kind designed specifically to provide simulated underground environmental conditions for the testing of heat transfer equipment.

The effective distribution of refrigeration to underground workings is indispensable for safe and profitable gold mining. The installed refrigeration capacity in the South African gold mines in 1983 was approximately 800 MW(R) and more than 75 per cent of this refrigeration is distributed to heat exchangers of various types, in which chilled water is used to cool the ventilation air.

To mines these heat exchangers represent a considerable investment, in terms of both capital and running costs. Continuing research is thus needed to ensure that the varying, increasingly-stringent demands of the industry can be satisfied for cost-effective equipment for conditioning the underground environment.

## THE NEED FOR A HEAT EXCHANGER TEST CENTRE

It is essential that research and development on heat exchangers be carried out under the thermal conditions in which they are to operate. Up until now the Research Organization has had to conduct most of the testing underground in mine workings, whenever and wherever suitable locations could be found. The bulk of this research could however be done more quickly and cost effectively in a surface test facility capable of simulating the underground environment. No such facility has previously been available.

The advantages of a surface test centre include:

- the important variables such as air and water flow rates, temperatures, and air humidity can be varied and controlled more conveniently than is possible in mine sites;
- the sophisticated measuring and data processing equipment required for the test programmes does not have to be protected from the rigours of the underground environment;
- heat exchangers to be evaluated can be installed and tested rapidly; and
- the test data can be processed and evaluated almost immediately.

The Heat Exchanger Test Centre will greatly facilitate preliminary, and routine testing, as well as fundamental studies on heat and mass transfer, under controlled conditions. This facility will, however, not replace underground evaluation, which will always ultimately be required to confirm the laboratory results and ascertain whether the equipment can operate satisfactorily under actual mining conditions. In addition new types of heat exchangers can be evaluated for the industry.

# TECHNICAL DESCRIPTION

The Centre is housed in one of the main buildings at the Carlow Road complex of the Research Organization, and forms part of the Environmental Engineering Laboratory. The main sections are:

- two test bays;
- a refrigeration installation;
- a water circuit; and
- an air circuit.

## Test bays

The test bays each occupy a floor area of 10 x 2,5 m. In these bays a supply of hot humid air (at temperatures similar to those found in deep gold mines) can be provided, as well as cold water at temperatures similar to those available from underground or surface mine refrigeration plants.

## The refrigeration installation

A 230 kW(R) screw-compressor refrigeration machine, located near the test bays, is used to provide hot water from the condenser and the cold water from the evaporator. The whole system has been designed to conserve energy; the total electrical power consumption is less than 150 kW. The technical specifications of the system are:

Air flow rate	:	up to 12 m <sup>3</sup> /s
Fan air pressure at design flow rate	:	up to 2 kPa
Water flow rate	:	up to 15 l/s
Cooling duty	:	up to 230 kW
Heating duty	:	up to 300 kW
Water temperature (minimum)	:	4 °C
Air temperature (maximum)	:	30 °C (saturated)



## Air circuit

The air circuit provides the test bays with a flow of air at the temperature and humidity needed to simulate the underground environmental conditions selected for the test.


Air is drawn by a centrifugal fan through the humidifier where it is heated and humidified. The airflow is then divided, with some air flowing to the heat exchanger test bays and the balance by-passed back to the humidifier. This by-pass arrangement ensures that the fan operates near to its design conditions even though the air flow through the test section may vary between 1 m<sup>3</sup>/s and 12 m<sup>3</sup>/s. Ambient air can also be introduced into the air circuit to extend the range of test conditions.

The gap between the wet-bulb and dry-bulb temperatures of the air being fed to the test bays may be controlled by a 30 kW electrical heater.

The air from the humidifier is passed into a measuring section fitted with a set of nine nozzles designed to an ASHRAE standard. By selecting various combinations of the test nozzles, flow rates between 0.5 m<sup>3</sup>/s and 12 m<sup>3</sup>/s can be measured accurately.

The air is then directed to one of the two test bays before returning to the humidifier for re-heating and humidifying.

The energy requirement is minimized by operating in a closed circuit. The energy supply needed to increase the wet-bulb temperature of 12 m<sup>3</sup>/s of air from 5 °C to 30 °C would be over 1 000 kW in a once-through system but, by using a closed loop, this has been reduced to 230 kW.



Air circuit

# THE USES OF THE HEAT EXCHANGER TEST CENTRE

The Research Organization is currently devoting considerable attention to devising methods for reducing the heat and pollutant load on the underground environment, and to improving methods for conditioning this environment. This includes the following types of investigations.

## Fundamental work on heat and mass transfer

Research in this area will give a better understanding of the heat and mass transfer processes which take place at near-saturation conditions, similar to those found in deep mines.

## Heat transfer and pressure drop characteristics of the various cooling coils


A knowledge of these characteristics is necessary to design both improved cooling coils and improved water distribution systems, and to determine the optimum operating conditions of these heat exchangers. Investigations will also be carried out into the effect of air flow distribution on cooling coil performance. It is generally recognized that fouling is one of the major problems associated with cooling coil performance, and its effect will be evaluated together with methods of cleaning the coils while in service.

## Development of dust filtration equipment


Water spray chambers provide a method of filtering large volumes of ventilation air underground with minimal energy expenditure. The performance characteristics of various spray nozzles and the effect of water spray pressure on the filtering efficiency are being studied.

## Development of spray air coolers

Direct-contact air coolers are more suitable for some situations than cooling coils and heat exchangers using spray systems with and without packing are presently being studied.




Free-standing Spray Mesh Cooler prototype designed for a nominal duty of 500 kW, a water flow of 7.5 l/s and an air flow of 10 m<sup>3</sup>/s. The unit is 2,8 m long x 1,4 m wide x 2,5 m high.



Schematic of free-standing Spray Mesh Cooler prototype

299  
Development of slope air coolers

A programme to develop heat exchangers which may be used to provide *in situ* cooling in narrow slopes has commenced. These heat exchangers use the water pressure (by means of turbines) to create the air flow and thus obviate the need for a supply of electrical power.



A one metre diameter slope air cooler designed for a water supply pressure of 400 kPa, a water flow of 1.8 l/s and a nominal cooling duty of 30 kW. The air flow of 1.2 m<sup>3</sup>/s is induced by a 480 mm diameter fan driver, by a 100 mm diameter Pelton wheel. Fan, fan shaft, Pelton wheel and bearing housings are shown together with a sample of plastic mesh heat exchanger packing.

# TECHNICAL ASSISTANCE


The Heat Exchanger Test Centre will augment the service provided by the Research Organization to the mining industry in testing the performance of new types of heat exchangers.

**For further information please contact:  
The Director,  
Environmental Engineering Laboratory,  
Research Organization,  
Chamber of Mines of South Africa,  
P.O. Box 809,  
Johannesburg, 2000.**

**Telephone 725-3020,  
Telex 4-26070 SA.**



**Chamber of Mines of South Africa  
Research Organization**



*Exterior view showing air humidifier, ducting and refrigeration plant room.*

**APPENDIX E    Specification of spray nozzles used in  
test tower**

The test tower made use of four nozzles spraying downwards with each nozzle producing a square water distribution pattern. The nozzles used were Spraying Systems Co. type 1½H230 SQ; specifications are given below:

**S**PRAYING SYSTEMS CO.

INDUSTRIAL

# SPRAY NOZZLES

AND ACCESSORIES



**S**PRAYING SYSTEMS CO.

*Engineers and Manufacturers*

3201 Randolph Street • Bellwood, Illinois 60154

Telephone: AREA CODE 312 Linden 4-0380 • Cable Address: SPRAYSYCO

# FullJet NOZZLES


## square spray

Spray Characteristics—Square spray pattern with good distribution throughout square pattern. Good atomization at all pressures.

Construction—Nozzles made with removable, internal offset vanes. Types

G and GG have replaceable caps.

Materials—Supplied standard in brass, steel and types 303 and 316 stainless steel (cast stainless steel type H-SQ in type 316 only). Other materials available on special order.



Square Spray Pattern	Nozzle No.		Pipe Conn. NPT	Drill Size	Max. Free Passage Diam.	CAPACITY (gallons per minute) at p.s.i. (pounds per square inch)												SPRAY ANGLE		
	Female Pipe Conn.	Male Pipe Conn.				5	7	10	20	30	40	60	80	100	150	7	70	80		
						p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	p.s.i.	
 Type HH-SQ male connection	WG2.8 SQ.	WG03.6 SQ.	1/4"	3/16"	.050"	.26	.31	.35	.50	.60	.69	.83	.95	1.1	1.3	40°	52°	47°		
	WG6 SQ.	WG06 SQ.	1/4"	3/8"	.050"	.43	.51	.60	.83	1.0	1.1	1.4	1.6	1.8	2.1	60°	66°	60°		
	WG10 SQ.	WG010 SQ.	1/4"	1/2"	1/4"	.72	.85	1.0	1.4	1.7	1.9	2.3	2.6	2.9	3.5	62°	67°	61°		
	WG12 SQ.	WG012 SQ.	1/4"	3/4"	1/4"	.88	1.0	1.2	1.7	2.0	2.3	2.8	3.2	3.5	4.3	70°	75°	68°		
	WG18 SQ.	WG018 SQ.	1/4"	3/4"	3/8"	1.3	1.5	1.8	2.5	3.0	3.4	4.1	4.7	5.3	6.4	71°	75°	68°		
	WG29 SQ.	WG029 SQ.	1/4"	3/4"	1/2"	2.1	2.5	2.9	4.0	4.8	5.5	6.7	7.6	8.5	10.0	71°	75°	68°		
	 Type HH-SQ male connection	WHH3.6 SQ.	WHH4.0 SQ.	1/4"	3/16"	.050"	.26	.31	.36	.50	.60	.69	.83	.95	1.1	1.3	40°	52°	47°	
		WHH4.0 SQ.	WHH4.8 SQ.	1/4"	1/4"	.050"	.34	.40	.48	.66	.80	.91	1.1	1.3	1.4	1.7	48°	63°	57°	
		WHH6 SQ.	WHH8 SQ.	1/4"	3/8"	.050"	.43	.51	.60	.83	1.0	1.1	1.4	1.6	1.8	2.1	62°	71°	65°	
		WHH10 SQ.	WHH12 SQ.	1/4"	3/8"	1/4"	.72	.85	1.0	1.4	1.7	1.9	2.3	2.6	2.9	3.5	62°	67°	61°	
WHH12 SQ.		WHH15 SQ.	1/4"	1/2"	1/4"	.88	1.0	1.2	1.7	2.0	2.3	2.8	3.2	3.5	4.3	70°	75°	68°		
WHH18 SQ.		WHH29 SQ.	1/4"	3/4"	1/2"	1.3	1.5	1.8	2.5	2.4	2.8	3.3	3.8	4.2	5.1	78°	82°	75°		
WHH29 SQ.		WHH36 SQ.	1/4"	3/4"	3/4"	2.1	2.5	2.9	4.0	4.8	5.5	6.7	7.6	8.5	10.0	71°	75°	68°		
WHH36 SQ.		WHH49 SQ.	1/4"	3/4"	1"	2.6	3.1	3.6	5.0	6.0	6.9	8.3	9.5	10.5	12.0	78°	82°	75°		
WHH49 SQ.		WHH59 SQ.	1/4"	3/4"	1 1/4"	3.7	4.3	5.0	7.0	8.4	9.6	11.3	12.2	14.6	17.6	71°	75°	68°		
 Type GG-SQ with removable cap male connection		1H106 SQ.		1"	3/4"	3/4"	7.6	8.9	10.6	14.5	17.5	20	24	26	31	37	78°	80°	73°	
	1 1/2H177 SQ.		1 1/2"	1"	1"	12.6	15.0	17.7	25	30	34	41	47	52	63	78°	80°	73°		
	1 3/4H230 SQ.		1 3/4"	1 1/4"	1 1/4"	13.5	23	32	39	44	53	61	67	80	73°	70°	70°			
	2H290 SQ.		2"	1 3/4"	1 3/4"	21	25	29	40	46	55	67	78	85	100	66°	70°	64°		
	2H360 SQ.		2"	1 3/4"	1 3/4"	26	31	36	50	60	69	83	95	105	130	70°	74°	67°		
	2H480 SQ.		2"	1 3/4"	1 3/4"	34	40	46	65	80	91	110	125	138	166	79°	82°	74°		
	2 1/2H490 SQ.		2 1/2"	1 3/4"	1 3/4"	35	41	49	67	81	92	113	126	142	170	62°	67°	61°		
	2 3/4H590 SQ.		2 3/4"	1 3/4"	1 3/4"	43	50	59	81	99	113	136	155	173	208	75°	78°	71°		

\*Foreign matter with maximum diameter as listed can pass through nozzle without clogging.

### DIMENSIONS AND WEIGHTS

Nozzle No.	Net Weight	A	B
WG SQ.	1 oz.	1 1/4"	3/16" Hex.
WG SQ.	2 oz.	1 1/2"	1/8" Hex.
WG SQ.	3 oz.	1 3/4"	1/4" Hex.
WG SQ.	5 oz.	1 7/8"	3/8" Hex.
WG SQ.	1 oz.	1 1/4"	3/16" Hex.
WG SQ.	2 oz.	1 1/2"	1/4" Hex.
WG SQ.	3 oz.	1 3/4"	1/2" Hex.
WG SQ.	5 oz.	1 7/8"	3/8" Hex.
1" HH SQ.	1/2 oz.	3/4"	1/2" Diam.
1 1/4" HH SQ.	1 oz.	3/4"	3/8" Diam.
1 1/2" HH SQ.	1 oz.	1 1/4"	3/8" Diam.
1 3/4" HH SQ.	2 oz.	1 1/4"	1/2" Diam.
1 1/2" HH SQ.	5 oz.	1 3/4"	1 1/2" Diam.
1H SQ.	12 oz.	2 1/4"	1 1/4" Diam.
1 1/2H SQ.	1 lb.	3 1/4"	1 1/2" Diam.
1 3/4H SQ.	1 1/2 lb.	4"	2 1/4" Diam.
2H SQ.	2 1/2 lb.	5"	3" Diam.
2 1/4H SQ.	4 1/2 lb.	6 1/2"	3 3/4" Diam.


Type GG-SQ

Type GG-SQ

Type HH-SQ

Type H-SQ  
Bar Stock

Type H-SQ  
Cast Type



Type H-SQ  
cast type  
one piece body  
female connection

See pages 58 to 63 for  
spray nozzle accessories.

Patent Nos. 2,105,310  
and 3,101,825



# FullJet<sup>™</sup> NOZZLES wide angle square spray

**Spray Characteristics**—Full square spray pattern combined with an under 90° wide spray angle to provide maximum surface area coverage per nozzle. Distribution is uniform throughout the pattern cross section. Impact is low due to wide angle of spray.

**Construction**—Offered in a complete range of pipe sizes. Internal valves are removable.

**Materials**—Standard in brass, iron or steel, and stainless steel. Other special materials can be supplied to order.

**Recommended For**—Multi-nozzle installations such as air and gas washers and rubber, liquid washers and web sprayers. Square spray patterns permit use of fewer nozzles per linear foot to provide complete and uniform coverage of area sprayed.

Wide Angle Square Spray Pattern




Nozzle No.		Pipe Conn. Size NPT	Orifice Diam.	Maximum Free Passage Dia. *	CAPACITY GPM (gallons per minute) at p.s.i. (pounds per square inch)						SPRAY ANGLE		
Female Pipe Conn.	Male Pipe Conn.				5 p.s.i.	10 p.s.i.	20 p.s.i.	40 p.s.i.	60 p.s.i.	80 p.s.i.	5 p.s.i.	10 p.s.i.	20 p.s.i.
	½ HH14WSQ	¼"	⅛"	⅛"	1.0	1.4	1.9	2.6	3.1	3.5	99°	101°	93°
	½ HH20WSQ	¼"	⅜"	⅜"	1.5	2.0	2.7	3.6	4.4	5.0	104°	110°	94°
	½ HH35WSQ	¼"	½"	½"	2.6	3.5	4.9	6.7	8.2	9.3	104°	110°	102°
¾ HH71WSQ	¾ HH71WSQ	¾"	¾"	¾"	5.1	7.1	10	13.9	16.9	19.4	105°	110°	102°
1 HH130WSQ	1 HH130WSQ	1"	¾"	¾"	8.8	13	18	25	31	35	107°	110°	107°
1 ½ HH190WSQ		1 ½"	¾"	¾"	13.6	19	27	37	45	52	108°	111°	109°
1 ¾ HH250WSQ		1 ¾"	¾"	¾"	20	29	40	55	66	76	109°	114°	109°
2 HH560WSQ		2"	¾"	¾"	40	56	79	110	135	154	110°	114°	109°
2 ½ HH830WSQ		2 ½"	¾"	¾"	59	83	117	164	200	230	110°	115°	109°
3 HH1070WSQ		3"	¾"	¾"	81	107	149	208	250	290	110°	115°	109°

\* Foreign matter with maximum diameter as listed can pass through nozzle without clogging.

Patent No. 2,308,210  
and Patents Pending

## DIMENSIONS AND WEIGHTS

Nozzle No.	A (length)	Ø (diameter)	Net Weight
½ HH	1 1/8"	1 1/8"	1/2 oz.
¾ HH	1 3/8"	1 3/8"	1 oz.
1 HH	1 7/8"	1 7/8"	1 1/2 oz.
1 ½ HH	2 1/4"	1 7/8"	3 oz.
1 HH	2 1/2"	1 7/8"	7 oz.
1 ½ H	2 1/2"	1 7/8"	7 oz.
1 H	2 3/4"	1 7/8"	11 oz.
1 ¾ H	3 1/4"	2 1/8"	1 1/2 lbs.
1 ½ H	4 1/2"	2 1/8"	2 lbs.
2 H	5 1/2"	3"	3 1/2 lbs.
2 ½ H	6 1/2"	3 1/2"	4 1/2 lbs.
3 H	7 1/2"	4 1/2"	6 1/2 lbs.



Type H female conn. (bar stock) nozzle numbers ½ H and 1 H



Type HH male conn. (bar stock) nozzle numbers ½ HH through 1 ½ H



Type H female conn. (casting) nozzle numbers 1 ¾ H through 3 H

Type H (bar stock) female connection ½ H and 1 H



Type H cast female connection 1 ¾ H through 3 H

See page 64 for spray coverage and application information.

**APPENDIX F      Specification of mist eliminator mesh  
used in test tower**

The mist eliminator used in the test tower consisted of four layers of interlaced plastic mesh in the form of a mat. The design used was Kimre Inc type 16/96; specifications are given below:


# Style 8/96 Polypropylene

**Kimre, Inc. has developed  
a unique new product  
with special application to  
vapor-liquid processes.**

The B-Gon<sup>®</sup> mist eliminator and Kon-Tane<sup>®</sup> tower packing utilize interlaced monofilaments with essentially all of the filaments oriented perpendicular to the gas flow.

Both products are exceptionally stable, both dynamically and statically, since each filament reinforces those closest to it. Kimre mist eliminators and tower packing are different from any other products available. They are available in various filament materials and diameters, providing a large range of applications to vapor-liquid mass transfer and separation processes.

Specific data on the available styles, filament sizes and free void space, and applications for B-Gon mist eliminators and Kon-Tane tower packing is available from Kimre, Inc. This data also includes test results: HTUs, Pressure Drop Characteristics and Mass Transfer Coefficients.



B-Gon provides high efficiency removal of the liquid phase from the vapor phase, and low pressure drop through the material, allowing higher throughput at lower energy usage.

B-Gon achieves maximum impingement with lower drag because essentially all of its filaments are aligned perpendicular to the gas flow, rather than in the random arrangement common to knitted wire mesh materials. In addition, the B-Gon mist eliminator combines the best features of knitted wire and plate type eliminators. The ladder arrangement of the two sets of filaments causes a change in direction of vapor flow which aids in droplet removal by centrifugal action and also produces a cross flow of the removed water that flushes particulates from the media. The table below shows the efficiency of the B-Gon style 16/96 under test conditions.

#### Test Data -- Style 16/96 (1.75" Dia.)

Velocity, Ft/Sec	ΔP Inches H <sub>2</sub> O	Efficiency: %					
		Drop Diameter, Microns					
		2-4	4.5	6-8	8-10	10-12	10-14
5.2	.42	98.73	99.49	99.92	99.96	99.99	99.99
8.2	1.08	99.30	99.56	99.78	99.92	99.96	99.99

The efficiency data, obtained by Calspan Corporation, is valid to the nearest 0.1%. The tests were done using water fogs in a saturated atmosphere.

#### Sizes and Filament Diameters

B-Gon mist eliminators are available in sizes up to 6 feet by 20 feet. In the great majority of applications, this size range eliminates the need for placing B-Gon mist eliminators are available in filament diameters from 4 mills to 62 mills, and various void fractions, which provide a wide range of physical characteristics for individual applications.

B-Gon is stock manufactured from either polypropylene or Kynar. (Kynar is the registered trademark for Pennwalt Corporation's polyvinylidene fluoride resin.)

#### Design Information and Examples

**Efficiency** -- The amount of liquid passing through the eliminator without being captured may be expressed as  $PI = \exp(-K_1^2 N)$  or  $-\ln(PI) = K_1^2 N$ .

The value of  $K_1^2$  is determined experimentally, or estimated from theory. Results for style 16/96 are shown in Figure 1.

**Example** -- To achieve a desired 99.9% efficiency of removal at a gas velocity of 5 fps for 3 micron droplets one calculates:

$$-\ln(PI) = -\ln(1-0.999) = -\ln(0.001) = 6.93$$

From Figure 1 for 16/96 at a velocity of 5 (ps,  $K_1^2$  is found

$$K_1^2 = 0.452 = \frac{-\ln(PI)}{N} \quad N = 15.3 \text{ layers, use 16.}$$

**Pressure Drop** -- Pressure drop through a mist eliminator can be related by:

$$\Delta P = K_2^2 \times V^2 \times N$$

For style 16/96 with air at 760 mmHg and 75°F. at low liquid rates this expression becomes:

$$\Delta P = 1.7 \times 10^{-5} \times V^2 \times N$$

**Example** -- For the example above, the pressure drop is calculated to be:

$$\Delta P = 1.7 \times 10^{-5} \times 5^2 \times 16 = 0.68 \text{ inches H}_2\text{O.}$$

#### General Type


$PI$  = Penetration =  $(1 - \text{efficiency}) = \text{Fraction Amount passing}$



$N$  = Number of layers.

$K_1^2$  = Variable relating the geometry of the material, drop size, and gas velocity with drop removal effectiveness

$K_2^2$  = Variable relating the geometry of the material, liquid loading and pressure drop.

Figure 1. Effectiveness of B-Gon Style 16/96





## Kon-Tane Tower Packing

Kon-Tane is an interlaced monofilament material for tower packing use. The material is designed to provide excellent breakup of the liquid phase, creating maximum surface area for mass transfer with the vapor phase. Its properties reduce low pressure drop, prevent liquid holdup on and within the packing, and prevent excessive energy usage.

Its ladder-like arrangement of filaments or cylinders forms V-type double systems which intersect each other at right angles. A drop falling from one of the cylinders almost immediately hits the next, making new liquid surface available for mass transfer.

The range of filament diameters from which Kon-Tane can be manufactured permits use of larger diameter cylinders. These cylinders offer relatively less resistance to vapor flow due to lower surface area. It also permits variation in the void fraction of the material to suit process requirements.

While having approximately the same dry pressure drop ratings as 1 1/2" Raschig rings, Kon-Tane Style 37/94 does not flood at liquid feed rates in excess of 8500 lbs/hr/ft<sup>2</sup>. Due to its inherent rigidity and strength, Kon-Tane can be installed in layered pads many feet thick using relatively simple supports. The material is flexible enough for the layers to be inserted through a manhole. Because of the uniform cross section of the material edge to edge, channelling at the wall of the vessel and throughout the material is minimized.

Kon-Tane tower packing is available in layered pads up to 6 inches in depth and 6 feet in diameter, and sheets up to 6 feet by 20 feet. Larger sizes can be manufactured in multiple-piece pads. Filament diameters are available from 16 mils to 62 mils. Kon-Tane tower packing is available in a variety of styles (see back page) manufactured from Kynar (Kynar is the trademark for Pennwalt Corporation's polyvinylidene fluoride resin), and polypropylene. Kynar will handle virtually any corrosive application up to 230°F. For higher temperature applications, other materials are available on special order.

*Kon-Tane tower packing is available in layers up to 6 inches in depth and 6 feet in diameter.*


*Ladder-like arrangement of filaments forms V-type double systems which intersect each other at right angles.*

*B-Gon and Kon-Tane utilize interlaced monofilaments with essentially all filaments oriented perpendicular to the gas flow.*

**APPENDIX G      Specification of packing or fill used in  
test tower**

The packing medium consisted of corrugated sheets joined together in a fluted configuration. The packing used was the 12 mm and 19 mm flute size fill supplied by Munters Euroform; specifications are given below:


# Kühleinbau Cooling Tower Fill C10 Kyltornsfyllning



Drainagesystem  
Drainage system  
Drainagesystem

D-5100 Aachen  
P. O. Box 1089  
Phone 0241/48411  
Telex 8 32 473

Typ Type Typ	C 10.12	C 10.15	C 10.19	C 10.27
Flute size Flute size Vellhöjd	12 mm	15 mm	19 mm	27 mm
Austauschfläche Surface of exchange Kontaktyta	243 m <sup>2</sup> /m <sup>3</sup>	187 m <sup>2</sup> /m <sup>3</sup>	148 m <sup>2</sup> /m <sup>3</sup>	112 m <sup>2</sup> /m <sup>3</sup>
Min. Regendichte Min. water load Vattenbelastning	8 m <sup>3</sup> /m <sup>2</sup> h	8 m <sup>3</sup> /m <sup>2</sup> h	5 m <sup>3</sup> /m <sup>2</sup> h	3 m <sup>3</sup> /m <sup>2</sup> h
Werkstoffe Materials Material	PVC	PVC	PVC	PVC
Materialstärke Material size Materialtjocklek	0,20 mm	0,20 mm	0,25 mm	0,40 mm
Gewicht Weight Vikt	35 kp/m <sup>3</sup>	29 kp/m <sup>3</sup>	27 kp/m <sup>3</sup>	28 kp/m <sup>3</sup>
Drainagesystem Drainage system Dränagesystem	HVT/AT	AT	AT	-
Standardabmessungen Standard dimensions Standarddimensioner	1200 x 300 x 300 mm			

**C10****CONSTRUCTION OF FILL:**

CORRUGATED SHEETS ARE  
PILED UP AND JOINED  
TOGETHER WITH AN AD-  
HESIVE OF SAME QUAL-  
ITY AS FOIL MATERIAL.  
ALTERNATING POSITION OF  
SINGLE SHEETS GIVES  
HIGH STRENGTH.

ADDITIONAL REINFORCEMENT  
AND PROTECTION AGAINST  
DAMAGE OF SHEET EDGES BY  
CAPSIZING THE SHEET ENDS.

**THERMAL QUALITIES:**

HIGH EXCHANGE RATE AT COM-  
PARABLY LOW PRESSURE DROP.  
THE MATERIAL STRUCTURE  
EFFECTS A SUFFICIENT TUR-  
BULENCE OF GASEOUS AND  
FLUID PHASES.

FLUTE SIZE OF SEVERAL DI-  
MENSIONS FOR VARIOUS THER-

MAL SPECIFICATIONS. DRAINAGE SYSTEMS FOR HIGH WATER LOADS WHICH STOP  
THE PRESSURE DROP.

**MATERIALS:**

RIGID PVC (FLAME RESISTANT)  
ASBESTOS (FIRE PROOFED)

**APPLICATION:**

CROSS OR COUNTER FLOW



**APPENDIX H      Expected uncertainty in the measurement  
of the energy balance**

The uncertainty in each of the primary measurements have been estimated in the main text. This appendix shows, for a limited number of examples, how these uncertainties are propagated in the determination of the overall heat balance.

Table H.1 Expected uncertainty in the measurement of the energy balance

Parameter	Units	Value	EXAMPLE 1A		EXAMPLE 1B		EXAMPLE 2A		EXAMPLE 2B		EXAMPLE 3A		EXAMPLE 3B				
			Uncertainty in measurement 95% confidence limits	Balanced Data	Uncertainty in heat balance due to uncertainty in measurement <sup>1</sup>	Combination of uncertainties to cause most detrimental heat in-balance	Uncertainty in heat balance due to uncertainty in measurement <sup>1</sup>	Combination of uncertainties to cause most detrimental heat in-balance	Uncertainty in heat balance due to uncertainty in measurement <sup>1</sup>	Combination of uncertainties to cause most detrimental heat in-balance	Uncertainty in heat balance due to uncertainty in measurement <sup>1</sup>	Combination of uncertainties to cause most detrimental heat in-balance	Uncertainty in heat balance due to uncertainty in measurement <sup>1</sup>	Combination of uncertainties to cause most detrimental heat in-balance			
Air flow rate	kg/s	25	1.81	2.00	1.98	2.00	1.94	4.81	2.00	5.14	6.36	2.03	6.23	6.94	2.00	6.80	
Inlet wet-bulb temp.	°C	17	29.00	0.78	28.90	11.00	0.21	11.10	29.00	0.89	28.90	11.00	1.47	28.90	11.00	0.53	11.10
Inlet dry-bulb temp.	°C	17	34.00	0.03	33.90	18.00	0.03	33.90	18.00	0.03	33.90	18.00	0.03	33.90	18.00	0.03	18.10
Outlet wet-bulb temp.	°C	17	11.30	0.38	11.40	37.00	0.63	36.90	14.50	0.49	14.60	32.00	0.71	11.90	21.00	0.94	24.90
Outlet dry-bulb temp.	°C	17	11.80	0.00	11.90	37.00	0.00	36.90	15.00	0.00	15.10	32.00	0.00	31.90	21.50	0.00	21.90
Water flow rate	kg/s	25	12.00	2.00	12.24	12.00	2.00	12.24	6.00	2.00	6.12	3.00	2.00	3.06	3.00	2.00	3.06
Inlet water temp.	°C	17	10.00	3.76	9.95	41.00	1.92	41.00	10.00	0.84	9.95	41.00	0.50	9.95	41.00	0.36	41.05
Outlet water temp.	°C	17	12.56	3.72	12.66	36.10	1.96	36.00	21.68	0.84	21.76	32.30	0.51	22.30	29.13	0.32	12.96
Heat balance ratio	-	-	1.00	-	0.90	1.00	-	0.93	1.00	-	0.94	1.00	-	0.94	1.00	-	0.94
Uncertainty in heat balance ( $e_2 + e_3 + e_4 + e_5 + e_6 + e_7 + e_8 + e_9 + e_{10}$ )	-	-	-	6.07	-	4.00	-	3.23	-	3.02	-	3.40	-	3.06	-	3.06	-

Continued/...

	Uncertainty in measurement 95% confidence limits	EXAMPLE 4A			EXAMPLE 4B			EXAMPLE 5A			EXAMPLE 5B			EXAMPLE 6A			EXAMPLE 6B			
		Balanced Data	Uncertainty in heat balance due to uncertainty in measurement $\frac{1}{2}$	Combination of un- certainties to cause most detrimental heat in-balance	Balanced Data	Uncertainty in heat balance due to uncertainty in measurement $\frac{1}{2}$	Combination of un- certainties to cause most detrimental heat in-balance	Balanced Data	Uncertainty in heat balance due to uncertainty in measurement $\frac{1}{2}$	Combination of un- certainties to cause most detrimental heat in-balance	Balanced Data	Uncertainty in heat balance due to uncertainty in measurement $\frac{1}{2}$	Combination of un- certainties to cause most detrimental heat in-balance	Balanced Data	Uncertainty in heat balance due to uncertainty in measurement $\frac{1}{2}$	Combination of un- certainties to cause most detrimental heat in-balance	Balanced Data	Uncertainty in heat balance due to uncertainty in measurement $\frac{1}{2}$	Combination of un- certainties to cause most detrimental heat in-balance	
Air flow rate	kg/s	2t	1,82	2,00	1,78	1,98	2,00	1,94	4,80	2,00	4,70	5,24	2,00	5,13	6,34	2,00	6,22	6,92	2,00	6,78
Inlet wet-bulb temp.	°C	0,1 °C	29,00	0,03	28,90	11,00	0,21	11,10	29,00	1,73	28,90	11,00	0,52	11,10	29,00	3,03	28,90	11,00	1,30	11,10
Inlet dry-bulb temp.	°C	0,1 °C	34,00	0,03	33,90	18,00	0,03	18,10	34,00	0,03	33,90	18,00	0,03	18,10	34,00	0,03	33,90	18,00	0,03	18,10
Outlet wet-bulb temp.	°C	0,1 °C	12,00	0,40	12,70	37,00	0,63	36,90	22,50	1,31	22,60	25,00	0,91	24,90	25,50	2,60	25,60	17,50	1,67	17,40
Outlet dry-bulb temp.	°C	0,1 °C	12,50	0,00	12,60	37,00	0,00	36,90	24,00	0,00	24,10	25,00	0,00	24,90	26,50	0,00	26,50	18,50	0,00	18,50
Water flow rate	kg/s	2t	12,00	2,00	12,24	11,00	2,00	12,24	6,00	2,00	6,12	6,00	2,00	6,12	3,00	2,00	3,06	3,00	2,00	3,06
Inlet water temp.	°C	0,1 °C	10,00	3,90	9,95	41,00	1,92	41,05	10,00	1,58	9,95	41,00	0,92	41,05	10,00	1,06	9,95	41,00	0,90	41,05
Outlet water temp.	°C	0,1 °C	12,49	3,83	12,59	36,08	1,96	35,98	16,18	1,58	16,28	30,70	0,92	30,60	19,32	1,08	19,42	30,38	0,89	30,28
Heat balance ratio	-		1,00	-	0,90	1,00	-	0,93	1,00	-	0,91	1,00	-	0,93	1,00	-	0,90	1,00	-	0,92
Uncertainty in heat balance ( $e^2 + e^2 + \dots$ ) <sup>1/2</sup>	-			6,22			4,00			4,21			3,29			5,12				3,75

Table H.1 Expected uncertainty in the measurement of the energy balance

**APPENDIX I      Procedure for calculating heat balance  
                  and correcting data**

As discussed in the main text the heat flow from either stream is simply calculated by the change in enthalpy.

The change in mass flow rate of the water due to condensation or evaporation is determined by a mass balance with the air stream, since the inlet and outlet moisture content of the air is known. The logic for correcting the errors in the data to create a heat balance is also presented in the main text. The following computer listing gives the exact procedure used to achieve this.

```

16      !
17      !          PROCEDURE FOR CALCULATING HEAT BALANCE AND CORRECTING DATA
26      ! Only the relevant statements are shown
36      ! A(2) : Air pressure drop
46      ! A(3) : Water flow rate
56      ! A(4) : Air mass flow rate
66      ! A(5) : Air quantity
76      ! A(6) : Density of dry air
86      ! A(7) : Inlet water temperature
96      ! A(8) : Outlet water temperature
106     ! A(9) : Water temperature off packing
116     ! A(10) : Inlet wet-bulb temperature
126     ! A(11) : Inlet dry-bulb temperature
136     ! A(12) : Outlet wet-bulb temperature
146     ! A(13) : Outlet dry-bulb temperature
156     ! A(14) : Air duty
166     ! A(15) : Water duty
176     ! A(16) : Ratio of air duty / water duty
186     P2=93.5      ! Barometric pressure
196     ! CALCULATE NEW DUTY
206     G=0
216     P1=A(2)*.6895+P2
226     Fraction=.895
236     IF ABS(A(14))>ABS(A(15))<< THEN Fraction=.895
246     G=G+Fraction      !Fraction of maximum error
256     ! Calculate new temperature and flow
266     Gap1=A(11)-A(10)
276     Gap2=A(13)-A(12)
286     IF ABS(A(14))>ABS(A(15)) THEN A(5)=A(5)*(1-.82*G)
296     IF ABS(A(14))>ABS(A(15)) THEN A(3)=A(3)*(1+.82*G)
306     IF ABS(A(14))<ABS(A(15)) THEN A(5)=A(5)*(1+.82*G)
316     IF ABS(A(14))<ABS(A(15)) THEN A(3)=A(3)*(1-.82*G)
326     IF A(7)>A(10) THEN GOTO 426
336     IF ABS(A(14))>ABS(A(15)) THEN A(10)=A(10)-.14G
346     IF ABS(A(14))>ABS(A(15)) THEN A(12)=A(12)+.14G
356     IF ABS(A(14))>ABS(A(15)) THEN A(7)=A(7)-.14G
366     IF ABS(A(14))>ABS(A(15)) THEN A(8)=A(8)+.14G
376     IF ABS(A(14))<ABS(A(15)) THEN A(10)=A(10)+.14G
386     IF ABS(A(14))<ABS(A(15)) THEN A(12)=A(12)-.14G
396     IF ABS(A(14))<ABS(A(15)) THEN A(7)=A(7)+.14G
406     IF ABS(A(14))<ABS(A(15)) THEN A(8)=A(8)-.14G
416     GOTO 506
426     IF ABS(A(14))>ABS(A(15)) THEN A(10)=A(10)+.14G
436     IF ABS(A(14))>ABS(A(15)) THEN A(12)=A(12)-.14G
446     IF ABS(A(14))>ABS(A(15)) THEN A(7)=A(7)+.14G
456     IF ABS(A(14))>ABS(A(15)) THEN A(8)=A(8)-.14G
466     IF ABS(A(14))<ABS(A(15)) THEN A(10)=A(10)-.14G
476     IF ABS(A(14))<ABS(A(15)) THEN A(12)=A(12)+.14G
486     IF ABS(A(14))<ABS(A(15)) THEN A(7)=A(7)-.14G
496     IF ABS(A(14))<ABS(A(15)) THEN A(8)=A(8)+.14G
506     A(11)=A(11)+Gap1
516     A(13)=A(13)+Gap2
526     P1=P1+.82*A(5)*2      !Pressure at flow measuring point
536     Esat1=.6105*EXP(17.27*A(10)/(237.3+A(10)))
546     E1=Esat1*(3555.6-2.465*A(10)+1.895*A(11))-P1*.895*(A(11)-A(10))/(15
55.6+.139*A(11))-1.599*A(10)-Esat1*.14*(A(11)-A(10))/P1
566     A(6)=P1-E1/(1.287*(273.15+A(11)))      !Density
576     A(4)=A(5)*A(6)
586     Esat2=.6105*EXP(17.27*A(12)/(237.3+A(12)))
596     E2=Esat2*(3555.6-2.465*A(12)+1.895*A(13))-P2*.895*(A(13)-A(12))/(15
60.6+.139*A(13))-1.599*A(12)-Esat2*.14*(A(13)-A(12))/P2
616     A1=.622*E1/(P1-E1)      ! apparent specific humidity, W, of air in
626     A2=.622*E2/(P2-E2)      ! apparent specific humidity, W, of air out
636     MB=A(5)*A2-A(13)      !Mass transfer
646     A(15)=.4187*A(13)+A(7)-(A(13)-MB)*A(8)      !Water duty
656     H1=.895*A(11)+A1*(2581+1.84*A(11))      ! Enthalpy air in
666     H2=.895*A(13)+A2*(2581+1.84*A(13))      ! Enthalpy air out
676     A(14)=A(5)*A1*(H1-H2)      ! Air duty
686     A(16)=A(14)/A(15)      !Ratio air duty/water duty
696     IF ABS(A(14)/A(15))-1<.0001 THEN Dump_to_disk
706     GOTO 226
716     NEXT I
726     STOP
736     END

```

APPENDIX J Direct comparison between the overall transfer coefficient for evaporation tests and that for condensation tests

It is possible to predict the effects on the transfer coefficients of changes in temperature through an examination of the well established correlation for heat transfer data (eg, Equation J.1). Lefevre<sup>(102)</sup> has shown that the expectation is that the transfer coefficient will decrease with an increase in air and water temperature for the same water loading and air velocity. The indications are that this reduction might be of the order of 10 per cent for the full range of conditions considered here. However this sort of analysis has to inevitably be based on broad theoretical assumptions which have inherent limitations. Furthermore it is not clear how Lefevre took account of moisture content and its affect on the transport properties at the film condition. However, what could be significant is Lefevre's indication that the water phase thermal resistance appears to be highly affected by temperature conditions.

On the basis of the present set of data the opportunity existed to examine the effects on Nusselt number of variations in temperature on an experimental basis. As described in the main text, values of the overall heat transfer coefficient were determined for each of the 160 tests and listed in Table 5.2. The experimental programme was structured so that, for the same flow and geometry conditions, equivalent tests were done for cold water/hot air and hot water/cold air conditions. This allows the effects of these changes in temperature conditions and direction of mass transfer to be

examined directly and in isolation to the flow and geometry variables.

Heat transfer and mass transfer data are usually correlated in similar relationships as given by Equations 5.1 and 5.2. Through this similarity the mass transfer coefficient is related to the heat transfer coefficient. Recall that this approach is embodied in the computer simulator and thus an investigation of the overall energy transfer can focus attention on the heat transfer coefficient alone. Data on heat transfer coefficients are normally correlated through Equation 5.1, another common form of which is<sup>(96)</sup>:

$$Nu = a Re^b Pr^c \quad (J.1)$$

(This is simply another form of Equation 5.1 following minor algebraic manipulation. Although the same nomenclature is used, the exponent terms will have different values.)

Equation J.1 often takes the form where an additive term is included on the right-hand side<sup>(49)</sup>. Bearing in mind that the analysis is comparative and that, as will be seen, Equation J.1 is used simply as a tool for differential adjustments of the Nusselt terms, the relative merits of the various correlations will not be debated here.

As will be seen later (Table J.1) the value of the Prandtl number,  $Pr$ , does not vary significantly in the present set of tests. Furthermore, the value of the exponent,  $c$ , is usually small ( $c = 1 - z = 0,33$ ). Thus, variations in  $Pr$  do not play a significant part in the present comparative analysis and have been neglected.

The analysis now concentrates on the relationship:

$$\text{Nu} \propto \text{Re}^b \quad (\text{J.2})$$

which may be expanded to give :

$$\frac{h_c d}{k_{avf}} = a_1 \left[ \frac{\rho_{avo} V d}{\mu_{avf}} \right]^b \quad (\text{J.3})$$

The velocity term referred to above is that of the free air stream. Ideally this term should be the relative velocity of the air in relation to the water surface. Again, considering the comparative nature of the analyses and that Equation J.3 is simply used as a tool for differential adjustment, the effect of the water velocity has been ignored.

Recall that all the transport properties are evaluated at the film condition. However, note that the reference mass velocity of the bulk air stream is applicable to the calculation of the Reynolds number. (This becomes obvious from the model of Reynolds flux discussed in Chapter 2). Of further interest at this stage is that the Stanton number, based on mass transfer data, simply represents the ratio of the Reynolds flux to the reference mass velocity of the bulk air stream.

$$\text{St}_m = m_{fl} / \rho_{avo} V \quad (\text{J.4})$$

An evaluation of Equation J.3 requires a knowledge of

the values of the various transport properties. The representative values of these terms for each test have been determined by examining the experimental data in conjunction with the simulator. The computer simulator was used to determine the variation of the transport properties within the heat exchanger for each test and not only at the end states. This information was then used to determine, for each of the 160 tests, representative values of each of the transport properties within the heat exchanger. This has been done on a weighted mean basis with regard to the total heat transfer at each simulated section within the heat exchanger. These values are presented in Table J.1.

As mentioned earlier, note should be taken of the small variation in the value of  $Pr$ .

It will have been noted at this stage that the film coefficient and the surface area have been combined in a single overall term given as  $h_c A$ . It is impossible to determine independently the value of the surface area of contact available for heat and mass transfer. Apart from the difficulty in determining the surface area of the water drops in the spray above and below the packing, it is also apparent that the wetted area of the packing will depend on water flowrates.

The surface area is primarily a function of the packing geometry and the water flowrate; by matching these parameters it is possible to create an identical set of circumstances for cold water tests and for hot water tests in which the surface areas of contact are identical. Subsequent analysis can then be done on a comparative basis where ratios are taken and the surface area terms cancelled.

For each series of tests (both cold water/hot air and

cold air/hot water tests for each packing configuration) the water flowrate was varied from 3 to 12 l/s in four steps having nominal values of 3; 6; 9; and 12 l/s. For each of these water flowrates the flowrate of the air was varied from 2 to 7 kg/s, again in four steps with nominal values of 2; 3,7; 5,3; and 7 kg/s. Thus, each series of tests consisted of 16 sets of measurements at the nominal, standard flow settings. Practically, it was extremely difficult to control the flows to the exact nominal values and the actual values varied slightly. For a direct comparison of corresponding cold water and hot water tests, it was necessary to marginally adjust each of the measured values to the exact nominal conditions.

Including a surface area term in Equation J.3, gives:

$$\text{Nu.A} = \frac{h_c A d}{k_{\text{avf}}} = a_1 \left[ \frac{\rho_{\text{avco}} V d}{\mu_{\text{avf}}} \right]^b A \quad (\text{J.5})$$

For a single packing geometry, the surface area will be related to water flowrate, hence:

$$\text{Nu.A} = \frac{h_c A d}{k_{\text{avf}}} = a_1 \left[ \frac{\rho_{\text{avco}} V d}{\mu_{\text{avf}}} \right]^b f_1(m_w) \quad (\text{J.6})$$

For a meaningful comparison to be drawn between  $\text{Nu}_{\text{cold}}$  and  $\text{Nu}_{\text{hot}}$ , the terms on the right-hand side of Equation J.5 must be identical. (The subscripts cold and hot refer to the cold water/hot air and hot water/cold air tests respectively.) Marginal adjustments for the slight variations from the nominal values of each test were done on a differential basis using equations which

had been fitted to each of the 10 sets of test data. The fitting of these equations involved a correlation

$$\begin{aligned} \text{Nu.A} = & K_6 m_w + K_7 \text{Re} + K_8 m_w \text{Re} + K_9 m_w^2 + K_{10} \text{Re}^2 \\ & + K_{11} m_w^2 \text{Re} + K_{12} m_w \text{Re}^2 + K_{13} m_w^2 \text{Re}^2 \end{aligned} \quad (\text{J.7})$$

Results of the curve fitting exercise and values of the coefficients are shown in Table J.2. In each case the correlation was excellent.

Marginal adjustments to the actual values of Nu.A were then done through:

$$\Delta \text{Nu.A} = \frac{\partial (\text{Nu.A})}{\partial \text{Re}} \Delta \text{Re} + \frac{\partial (\text{Nu.A})}{\partial m_w} \Delta m_w \quad (\text{J.8})$$

where  $\Delta \text{Re}$  and  $\Delta m_w$  are the marginal differences between the measured and nominal values of Re and the water flowrate respectively.  $\Delta \text{Nu.A}$  is the marginal difference between that calculated from the measurements and the expected value at the nominal flow settings.

The adjusted nominal values have been compared by examining the ratio of the cold water/hot air values to the hot water/cold air values and the results given as the ratio of the Nusselt numbers in Table J.3.

Based on the well accepted historic use of the relationship  $\text{Nu} = a \text{Re}^b$ , the high quality of the data and the care taken to match equivalent cold and hot operating conditions, it should be expected that the ratio  $\text{Nu}_{\text{cold/hot}}$  would have values of close to unity.

From an examination of Table J.3 it can be seen that over the full range of tests, the value of the ratio  $Nu_{\text{cold/hot}}$  varied from 0,88 to 1,49. The value was generally greater than unity and on an average basis the value of  $Nu_{\text{cold}}$  was 7 per cent greater than the value of  $Nu_{\text{hot}}$ . However, the wide variation in these values is worth closer examination.

A careful consideration of the value of the  $Nu_{\text{cold/hot}}$  ratio has not identified any systematic and consistent relationship between its value and the main parameters such as the water flow, air flow, temperature conditions and any combination of these terms. For example, it was felt that there would be merit in examining the relationship between  $Nu_{\text{cold/hot}}$  and the ratio of the density of the film and free stream condition for the cold and hot conditions. This data is plotted in Figure J.1, and there is clearly no trend evident.

This observation and the wide variation in values of the  $Nu_{\text{cold/hot}}$  ratio identifies two main questions. First, is the value of  $h_c A$  calculated in the correct manner? Second, is the surface area term indeed identical for equivalent cold water and hot water tests? Each of these questions is discussed in turn below.

The basic equation for the total heat transfer from a wet surface is given as:

$$\dot{q}_t = h_c A ( t_w - t_{db} + \lambda B' ) \quad (J.9)$$

The definition of the transfer coefficient is intimately linked to the definition of the overall driving force term. However, once defined and measured, the

values of the transfer coefficient are correlated, for future use, in a manner that is essentially independent of the driving force conditions under which it was measured. Thus, the basic method of analysis uses two distinct terms and the underlying premise is that, in the true physical sense, the two parameters should be independent of each other.

[Note that, notwithstanding the above, the transfer coefficient does not really describe the physical mechanisms but rather the overall effects thereof.]

However, as discussed earlier, it can be expected that in the presence of mass transfer, the value of the mass transfer coefficient would be affected by the migration of vapour, and would depend on the extent of the mass transfer itself. This led to the introduction of the logarithmic correction term given below and shown graphically in Figure J.2.

$$\frac{h_c}{h_{c1}} = \frac{\ln(1+B)}{B} \quad (J.10)$$

Accepting the validity of this correction term and noting that it is included in the bracketed driving force term of Equation J.9, it seems acceptable to anticipate that the transfer coefficient and the overall driving force term would be independent. (Note that the value of the transfer coefficient is related to pure heat transfer data only.)

Thus, the value of  $Nu$  should be essentially independent of whether hot water or cold water is used. However, the large variation in the values in Table J.3 does not support this observation and generally  $Nu_{cold}$  is greater than  $Nu_{hot}$ .

The simplicity of the basic analogy and the basic logarithmic correction term must be questioned. Recall Goff's<sup>(41)</sup> comment quoted earlier with regard to 'inaccurate conjecture based upon an unwarranted faith in the ultimate simplicity of nature'; this may well be applicable here. Certainly Spalding emphasizes that the simple procedure must be abandoned for all except the roughest calculations. The present set of data appear to highlight these limitations.

One possible conclusion is that the logarithmic correction term does not comply with reality. Examining this issue more deeply indeed reveals some evidence of its inaccuracy. Spalding<sup>(67)</sup> discusses experimental data<sup>(80,81)</sup> which indicate that the driving force might have a more dominant effect on the value of the transfer coefficient than would be indicated through Equation J.10. Even more evidence of this strong dependency comes from theoretical laminar boundary layer studies. Evans<sup>(56)</sup> presents information for flow over a flat plate for various Prandtl and Schmidt numbers. Evans' findings are repeated in Figure J.2, for the appropriate Prandtl and Schmidt numbers. For the range of conditions being considered, the value of the driving force,  $B$ , varies between  $-0,1$  and  $+0,1$ . Figure J.2 indicates that for condensation situations (cold water), the value of the actual mass transfer coefficient might be as much as 3 per cent higher than determined by the basic logarithmic correction factor. The opposite effect occurs for the hot water situation. For extreme cases, the comparative differences could be as much as 6 per cent. (Note that the nature of the dependency is such that the transfer coefficient decreases as the conditions become more evaporative.)

If the multiplying factor resulting from the boundary layer studies had been used in place of the normal

logarithmic factor within the computer program for calculating the values of  $h_c A$ , then the resulting ratio of  $Nu_{\text{cold/hot}}$  would be somewhat decreased. Thus, here is some further evidence that the mass transfer affects the value of the transfer coefficient to a greater extent than the widely used logarithmic factor would predict.

These present arguments cannot be regarded as any proof of this fact, but it is an issue worth pursuing further. One possible solution might be the use of separate transfer coefficients for heat and mass transfer. This is an approach that a number of other researchers (87,88) have used. From practical point of view, the adoption of this approach would be unfortunate since the simplicity and user-friendliness of all the methods of analysis rely heavily on the use of a single combined transfer coefficient. Another course of action to follow would be the development of a heat and mass transfer analogy and a correction factor (for the mass transfer effect on the transfer coefficient) that would describe both this present set and other data. In such a development the basic premise must be that the transfer coefficient would be a reference value (applicable under circumstances of no mass transfer) which would be independent of the so-called corrected driving force. (The driving force term would include the analogy relationship and the effect of mass transfer correction factor.)

In essence, this proposal would be aimed at forcing  $Nu_{\text{cold/hot}}$  to take on a value of unity, which is to be expected from using the 'film' coefficient concept in the first place. Whatever course of action is taken, this present work has highlighted a number of limitations and has again indicated the need for an

independent, specific treatment for water-air systems (see Chapter 1).

The second question raised earlier was with regard to the surface areas being identical for the cold water and the hot water tests. Recall the assumption that the extent of the surface area would depend primarily on water flow, and that for the same water flow, the same wetted surface area would be created (for the same geometry), whether the water was hot or cold. Considering this in further detail, the interaction between air flow and water flow could be expected to affect the surface area to some extent. This interaction would be driven by phenomena related to Reynold's number. The prevailing logic has been that this effect was also accounted for by making the comparison of  $Nu_{cold}$  to  $Nu_{hot}$  at the same Reynold's air flow numbers. It should also be noted that the physical properties of water that would affect the formation of the water surfaces, namely density, viscosity and surface tension, do indeed vary over the range of conditions being considered. These properties are given in Table J.4. It can be seen that the viscosity varies by up to 300 per cent and the surface tension by 10 per cent over the full range of conditions. The mechanisms involved in the formation of all the water surfaces are extremely complex, but probably deserve some further research. Lefevre<sup>(102)</sup> indicates that the water phase thermal resistance could be significantly affected by changes in water temperature and, in examining the formation of the water surfaces, this aspect should also be investigated.

### Conclusions

- . Values of the ratio  $Nu_{\text{cold/hot}}$  are expected to have a value of close to unity. For the 90 sets of data the mean was 1,07 with a range from 0,88 to 1,49.
- . The wide range of values of  $Nu_{\text{cold/hot}}$  encountered is probably an indication of the limitations of the simple heat and mass transfer analogy employed and of the basic logarithmic correction term used to account for the effect of mass transfer on the transfer coefficient.
- . Two further areas of research outside the scope of the present study are suggested. The first is an examination of the heat and mass transfer analogy and the correction factor on the basic premise that  $Nu_{\text{cold/hot}}$  should equal unity. The second is a study of the effect of water viscosity and surface tension on the formation of wet surface areas in packed towers.




Figure J.1 Relationship between Nu.A and the ratio of the film to bulk stream air density




Figure J.2 Effect of the mass transfer driving force,  $B$ , on the mass transfer coefficient (multiplying factor)

TEST No.	FILM COND. K <sub>avf</sub> ×10 <sup>-2</sup> (W/mK)	FILM VISC. μ <sub>avf</sub> ×10 <sup>-5</sup> (Ns/m <sup>2</sup> )	FILM DENS. ρ <sub>avf</sub> kg/m <sup>3</sup>	BULK DENS. ρ <sub>a</sub> kg/m <sup>3</sup>	FILM SP. HEAT C <sub>avf</sub> J/kgK	FILM DIFF. D <sub>avf</sub> ×10 <sup>-5</sup> (m <sup>2</sup> /s)	Pr	Sc
1	2.591	1.829	0.964	0.945	1817	3.109	0.722	0.611
2	2.573	1.818	0.966	0.941	1821	3.097	0.722	0.609
3	2.559	1.810	0.960	0.937	1820	3.100	0.721	0.609
4	2.553	1.806	0.937	0.916	1819	3.173	0.721	0.609
5	2.581	1.823	0.967	0.951	1822	3.091	0.722	0.610
6	2.563	1.812	0.970	0.946	1820	3.072	0.721	0.609
7	2.553	1.806	0.962	0.943	1819	3.068	0.721	0.609
8	2.548	1.803	0.945	0.927	1819	3.142	0.721	0.609
9	2.597	1.827	0.962	0.936	1822	3.113	0.722	0.610
10	2.552	1.805	0.974	0.954	1818	3.052	0.720	0.609
11	2.541	1.799	0.966	0.951	1818	3.066	0.720	0.607
12	2.570	1.816	0.928	0.917	1821	3.214	0.722	0.609
13	2.567	1.815	0.966	0.945	1820	3.086	0.721	0.609
14	2.557	1.806	0.967	0.930	1819	3.075	0.721	0.609
15	2.551	1.805	0.962	0.946	1819	3.087	0.721	0.609
16	2.543	1.800	0.952	0.939	1818	3.114	0.720	0.607
17	2.617	1.845	0.950	0.995	1827	3.160	0.724	0.613
18	2.653	1.867	0.923	0.967	1835	3.270	0.720	0.617
19	2.659	1.871	0.902	0.944	1837	3.359	0.720	0.619
20	2.666	1.875	0.865	0.907	1840	3.515	0.732	0.620
21	2.611	1.841	0.951	0.977	1826	3.161	0.724	0.612
22	2.641	1.859	0.920	0.973	1832	3.255	0.727	0.616
23	2.650	1.865	0.900	0.940	1835	3.333	0.720	0.617
24	2.656	1.869	0.876	0.916	1830	3.463	0.730	0.619
25	2.620	1.852	0.939	0.909	1829	3.214	0.725	0.614
26	2.627	1.851	0.933	0.975	1829	3.231	0.725	0.614
27	2.642	1.860	0.912	0.950	1833	3.314	0.727	0.616
28	2.646	1.863	0.880	0.925	1835	3.411	0.720	0.617
29	2.615	1.844	0.940	0.906	1827	3.281	0.724	0.613
30	2.622	1.849	0.931	0.973	1829	3.235	0.725	0.614
31	2.634	1.856	0.915	0.933	1831	3.301	0.726	0.615
32	2.637	1.857	0.896	0.933	1833	3.373	0.727	0.616

Table J.1 Representative values of the thermodynamic transport properties (mean values weighted by total heat transfer for each of 100 segments of heat exchanger)

Continued/...

TEST No.	FILM COND. Kavf *10-2 (N/nK)	FILM VISC. $\mu$ avf *10-5 (Ns/m <sup>2</sup> )	FILM DENS. $\zeta$ avf kg/m <sup>3</sup>	BULK DENS. $\zeta_a$ kg/m <sup>3</sup>	FILM SP. HEAT Cavf J/kgK	FILM DIFF. Davf *10-5 (m <sup>2</sup> /s)	Pr	Sc
33	2.584	1.825	0.965	0.954	1022	3.101	0.722	0.610
34	2.544	1.813	0.976	0.963	1020	3.052	0.721	0.609
35	2.557	1.809	0.979	0.965	1019	3.038	0.721	0.608
36	2.558	1.809	0.977	0.962	1019	3.045	0.721	0.608
37	2.587	1.827	0.951	0.943	1023	3.145	0.722	0.610
38	2.562	1.811	0.967	0.957	1020	3.079	0.721	0.609
39	2.545	1.801	0.976	0.963	1018	3.039	0.720	0.607
40	2.562	1.811	0.964	0.956	1020	3.086	0.721	0.608
41	2.592	1.823	0.934	0.928	1023	3.149	0.722	0.610
42	2.558	1.809	0.951	0.943	1020	3.120	0.721	0.608
43	2.544	1.801	0.968	0.949	1018	3.089	0.721	0.607
44	2.563	1.812	0.946	0.941	1020	3.140	0.721	0.609
45	2.575	1.819	0.903	0.899	1022	3.304	0.722	0.610
46	2.554	1.807	0.922	0.917	1020	3.222	0.721	0.608
47	2.560	1.810	0.922	0.919	1020	3.231	0.721	0.607
48	2.559	1.810	0.921	0.917	1020	3.234	0.721	0.609
49	2.640	1.859	0.933	0.960	1032	3.230	0.727	0.616
50	2.640	1.859	0.934	0.967	1032	3.235	0.727	0.616
51	2.657	1.869	0.924	0.961	1036	3.274	0.729	0.618
52	2.665	1.874	0.918	0.959	1037	3.312	0.730	0.619
53	2.627	1.851	0.926	0.960	1030	3.256	0.726	0.615
54	2.628	1.852	0.928	0.959	1030	3.251	0.726	0.615
55	2.640	1.864	0.916	0.951	1034	3.304	0.728	0.617
56	2.656	1.869	0.909	0.940	1036	3.332	0.729	0.618
57	2.619	1.846	0.906	0.939	1030	3.320	0.726	0.614
58	2.615	1.844	0.912	0.941	1029	3.303	0.725	0.614
59	2.627	1.851	0.906	0.935	1031	3.331	0.726	0.615
60	2.640	1.864	0.898	0.925	1035	3.405	0.729	0.617
61	2.613	1.842	0.877	0.909	1030	3.430	0.726	0.614
62	2.607	1.839	0.881	0.909	1028	3.422	0.725	0.613
63	2.626	1.851	0.870	0.897	1032	3.400	0.727	0.615
64	2.643	1.861	0.890	0.890	1036	3.539	0.729	0.618

Table J.1 (Cont.)

Continued/...

TEST No.	FILM COND. Kavf *(0-2 (W/nK)	FILM VISC. $\mu$ avf *10-5 (Ns/m <sup>2</sup> )	FILM DENS. $\rho$ avf kg/m <sup>3</sup>	BULK DENS. $\rho$ a kg/m <sup>3</sup>	FILM EP. HEAT Cavf J/kgK	FILM DIFF. Davf *10-5 (m <sup>2</sup> /s)	Pr	Sc
65	2.587	1.826	0.966	0.958	1823	3.117	0.722	0.618
66	2.568	1.818	0.976	0.969	1819	3.044	0.721	0.608
67	2.571	1.817	0.973	0.961	1821	3.066	0.722	0.609
68	2.562	1.812	0.973	0.962	1820	3.054	0.721	0.609
69	2.583	1.824	0.962	0.943	1823	3.172	0.722	0.618
70	2.564	1.813	0.962	0.957	1820	3.095	0.721	0.609
71	2.543	1.812	0.964	0.956	1820	3.088	0.721	0.609
72	2.552	1.806	0.968	0.956	1819	3.069	0.721	0.608
73	2.577	1.825	0.967	0.968	1822	3.292	0.722	0.618
74	2.558	1.809	0.937	0.935	1820	3.174	0.721	0.608
75	2.549	1.803	0.949	0.944	1819	3.127	0.721	0.608
76	2.545	1.801	0.949	0.948	1818	3.127	0.721	0.608
77	2.554	1.807	0.858	0.858	1820	3.462	0.722	0.609
78	2.549	1.804	0.888	0.888	1819	3.347	0.721	0.608
79	2.558	1.804	0.899	0.896	1819	3.311	0.721	0.608
80	2.547	1.802	0.905	0.899	1819	3.298	0.721	0.608
81	2.638	1.853	0.935	0.964	1838	3.229	0.726	0.615
82	2.635	1.866	0.923	0.954	1836	3.281	0.729	0.618
83	2.654	1.868	0.925	0.959	1835	3.273	0.728	0.617
84	2.668	1.876	0.915	0.952	1839	3.315	0.736	0.619
85	2.618	1.846	0.918	0.946	1829	3.282	0.726	0.614
86	2.643	1.861	0.908	0.937	1834	3.338	0.728	0.617
87	2.646	1.863	0.918	0.939	1835	3.328	0.726	0.617
88	2.666	1.871	0.908	0.933	1838	3.372	0.736	0.619
89	2.611	1.841	0.883	0.911	1829	3.411	0.726	0.614
90	2.633	1.858	0.876	0.903	1834	3.457	0.728	0.616
91	2.648	1.859	0.874	0.902	1835	3.467	0.729	0.617
92	2.654	1.868	0.864	0.894	1838	3.521	0.731	0.619
93	2.686	1.838	0.838	0.858	1838	3.635	0.727	0.614
94	2.625	1.858	0.821	0.848	1835	3.699	0.729	0.617
95	2.633	1.855	0.817	0.845	1836	3.729	0.738	0.617
96	2.658	1.865	0.812	0.843	1840	3.763	0.732	0.620

Table J.1 (Cont.)

Continued/...

TEST No.	FILM COND. Kavf $\times 10^{-2}$ (W/mK)	FILM VISC. $\mu$ avf $\times 10^{-5}$ (Ns/m <sup>2</sup> )	FILM DENS. $\rho$ avf kg/m <sup>3</sup>	BULK DENS. $\rho_b$ kg/m <sup>3</sup>	FILM SP. HEAT Cavf J/kgK	FILM DIFF. Davf $\times 10^{-5}$ (m <sup>2</sup> /s)	Pr	Sc
97	2.584	1.825	0.966	0.954	1822	3.897	0.722	0.610
98	2.561	1.811	0.970	0.965	1828	3.844	0.721	0.600
99	2.560	1.811	0.970	0.965	1828	3.843	0.721	0.600
100	2.566	1.814	0.973	0.959	1828	3.863	0.721	0.609
101	2.580	1.820	0.955	0.945	1823	3.133	0.722	0.611
102	2.589	1.827	0.957	0.951	1823	3.128	0.722	0.610
103	2.575	1.820	0.963	0.955	1821	3.899	0.722	0.609
104	2.568	1.815	0.964	0.952	1828	3.892	0.721	0.609
105	2.584	1.825	0.942	0.933	1823	3.175	0.722	0.610
106	2.566	1.814	0.953	0.944	1829	3.126	0.721	0.609
107	2.565	1.813	0.953	0.948	1828	3.125	0.721	0.609
108	2.561	1.811	0.952	0.945	1828	3.127	0.721	0.600
109	2.580	1.823	0.900	0.903	1823	3.289	0.723	0.610
110	2.574	1.819	0.922	0.918	1822	3.235	0.722	0.610
111	2.564	1.813	0.927	0.922	1821	3.213	0.722	0.609
112	2.558	1.809	0.925	0.918	1828	3.218	0.721	0.600
113	2.637	1.857	0.938	0.973	1831	3.220	0.726	0.615
114	2.651	1.866	0.938	0.966	1834	3.254	0.728	0.617
115	2.659	1.871	0.925	0.962	1835	3.274	0.729	0.618
116	2.665	1.874	0.920	0.959	1837	3.295	0.729	0.619
117	2.625	1.850	0.935	0.971	1829	3.225	0.725	0.614
118	2.638	1.858	0.928	0.962	1832	3.256	0.727	0.616
119	2.645	1.862	0.923	0.957	1832	3.276	0.727	0.616
120	2.655	1.868	0.915	0.953	1835	3.309	0.729	0.618
121	2.614	1.843	0.923	0.957	1828	3.282	0.725	0.613
122	2.629	1.852	0.916	0.948	1831	3.296	0.726	0.613
123	2.635	1.856	0.912	0.944	1832	3.312	0.727	0.615
124	2.649	1.864	0.901	0.936	1835	3.361	0.728	0.617
125	2.606	1.838	0.898	0.930	1828	3.350	0.725	0.613
126	2.621	1.847	0.891	0.922	1830	3.397	0.726	0.615
127	2.625	1.850	0.888	0.917	1831	3.400	0.726	0.615
128	2.642	1.860	0.873	0.906	1835	3.475	0.729	0.617

Table J.1 (Cont.)

Continued/...

TEST No.	FILM COND. Kavf *10 <sup>-2</sup> (N/mK)	FILM VISC. μavf *10 <sup>-5</sup> (Ns/m <sup>2</sup> )	FILM DENS. ρavf kg/m <sup>3</sup>	BULK DENS. ρa kg/m <sup>3</sup>	FILM SP. HEAT Cavf J/kgK	FILM DIFF. Davf *10 <sup>-5</sup> (m <sup>2</sup> /s)	Pr	Sc
129	2.573	1.818	0.976	0.955	1021	3.876	0.721	0.609
130	2.561	1.811	0.977	0.968	1020	3.847	0.721	0.608
131	2.551	1.805	0.982	0.970	1018	3.823	0.721	0.608
132	2.564	1.816	0.972	0.961	1021	3.068	0.721	0.609
133	2.504	1.825	0.949	0.947	1023	3.150	0.722	0.610
134	2.564	1.810	0.967	0.962	1022	3.077	0.721	0.609
135	2.555	1.809	0.970	0.961	1019	3.063	0.721	0.609
136	2.558	1.809	0.966	0.959	1019	3.078	0.721	0.609
137	2.577	1.821	0.925	0.924	1022	3.226	0.722	0.610
138	2.556	1.808	0.948	0.946	1019	3.134	0.721	0.609
139	2.561	1.811	0.948	0.939	1020	3.140	0.721	0.609
140	2.556	1.808	0.940	0.942	1019	3.136	0.721	0.609
141	2.545	1.814	0.885	0.884	1021	3.366	0.722	0.609
142	2.553	1.806	0.915	0.915	1019	3.247	0.721	0.609
143	2.549	1.803	0.923	0.920	1019	3.219	0.721	0.609
144	2.553	1.806	0.916	0.912	1019	3.249	0.721	0.609
145	2.614	1.843	0.946	0.972	1027	3.181	0.724	0.613
146	2.634	1.853	0.939	0.968	1030	3.212	0.726	0.615
147	2.639	1.858	0.935	0.967	1032	3.232	0.727	0.615
148	2.626	1.851	0.946	0.971	1029	3.200	0.725	0.614
149	2.602	1.836	0.937	0.961	1026	3.206	0.724	0.612
150	2.621	1.849	0.929	0.955	1029	3.245	0.725	0.614
151	2.632	1.854	0.924	0.953	1031	3.269	0.726	0.615
152	2.622	1.848	0.929	0.956	1029	3.247	0.725	0.614
153	2.594	1.831	0.914	0.938	1025	3.206	0.724	0.612
154	2.614	1.843	0.907	0.931	1029	3.325	0.725	0.614
155	2.626	1.851	0.901	0.927	1031	3.354	0.726	0.615
156	2.614	1.843	0.907	0.932	1028	3.324	0.725	0.613
157	2.598	1.829	0.874	0.898	1026	3.437	0.724	0.612
158	2.600	1.839	0.869	0.892	1029	3.474	0.726	0.614
159	2.621	1.847	0.868	0.885	1031	3.522	0.727	0.615
160	2.608	1.839	0.866	0.869	1029	3.493	0.725	0.613

Table J.1 (Cont.)

Continued/...

TEST NUMBERS	FLUTE	DEPTH mm	HOT/COLD WATER	R	K6	K7 $\times 10^{-4}$	K8 $\times 10^{-4}$	K9 $\times 10^{-2}$	K10 $\times 10^{-7}$	K11 $10^{-5}$	K12 $10^{-7}$	K13 $10^{-8}$
1 - 16	SPRAY ONLY		COLD	0,989	0,027	-8,71	3,63	0,07	4,47	-1,79	-1,71	1,15
17 - 32			HOT	0,997	0,084	-8,20	1,99	-0,73	5,21	0,33	-1,22	0,17
33 - 48	12	600	COLD	0,977	0,411	1,19	0,63	-2,61	-0,40	-0,08	0,55	-0,14
49 - 64	12	600	HOT	0,999	0,296	-6,27	5,16	-1,78	1,91	-3,53	-0,67	0,63
65 - 80	12	1 200	COLD	1,000	0,209	-4,73	9,83	-2,15	2,10	-4,53	-1,62	0,81
81 - 96	12	1 200	HOT	1,000	0,332	-4,59	8,74	-3,52	3,57	-3,05	-1,76	0,59
97 - 112	19	600	COLD	1,000	0,432	-4,15	3,64	-2,64	1,32	-1,95	-0,37	0,23
113 - 128	19	600	HOT	1,000	0,419	-6,25	3,93	-2,51	1,61	-2,26	-0,39	0,27
129 - 144	19	1 200	COLD	1,000	0,462	-2,81	5,30	-2,41	1,25	-2,95	-0,33	0,24
145 - 160	19	1 200	HOT	1,000	0,473	3,37	3,87	-6,14	1,05	-0,96	-0,41	0,11

Table J.2 Coefficients of curve fitting for  $Nu.A = f(Re, m_v)$

	NOMINAL WATER FLOW (kg/s)	NOMINAL AIR FLOW (kg/s)	NOMINAL AIR VELOCITY (m/s)	NOMINAL REYNOLD NUMBER	Nu.A Cold/Hot
	3,0	2,0	1,5	390	1,022
	6,0	2,0	1,5	390	1,054
	9,0	2,0	1,5	390	1,070
	12,0	2,0	1,5	390	1,202
	3,0	3,7	2,5	680	1,089
	6,0	3,7	2,5	680	1,099
	9,0	3,7	2,5	680	1,091
	12,0	3,7	2,5	680	1,164
	3,0	5,3	4,0	950	1,048
	6,0	5,3	4,0	950	1,187
	9,0	5,3	4,0	950	1,120
	12,0	5,3	4,0	950	0,989
	3,0	7,0	5,0	1 310	1,126
	6,0	7,0	5,0	1 310	1,189
	9,0	7,0	5,0	1 310	1,239
	12,0	7,0	5,0	1 310	1,202
					1,118 mean

**Note**

The characteristic dimension was taken as the flute size of the packing, that is 12mm or 19mm. For the spray situation a characteristic dimension of 5mm (approximating drop diameter) was used. However, the exact choice of these values is not important since the analysis involves direct comparison for similar geometries.

Table J.3 Ratio of Nu.A cold/hot for corresponding flow situations

Continued/...

TESTS	NOMINAL WATER FLOW (kg/s)	NOMINAL AIR FLOW (kg/s)	NOMINAL AIR VELOCITY (m/s)	NOMINAL REYNOLD NUMBER	Nu. A Cold/Hot
33-64 (12mm flute 0,6m deep)	3,0	2,0	1,5	900	0,995
	6,0	2,0	1,5	900	0,984
	9,0	2,0	1,5	900	1,002
	12,0	2,0	1,5	900	1,405
	3,0	3,7	2,5	1 603	0,979
	6,0	3,7	2,5	1 630	0,980
	9,0	3,7	2,5	1 630	1,069
	12,0	3,7	2,5	1 630	1,343
	3,0	5,3	4,0	2 470	0,973
	6,0	5,3	4,0	2 470	0,997
	9,0	5,3	4,0	2 470	1,086
	12,0	5,3	4,0	2 470	1,485
	3,0	7,0	5,0	3 520	1,011
	6,0	7,0	5,0	3 520	1,127
	9,0	7,0	5,0	3 520	1,239
	12,0	7,0	5,0	3 520	1,464
TESTS	NOMINAL WATER FLOW (kg/s)	NOMINAL AIR FLOW (kg/s)	NOMINAL AIR VELOCITY (m/s)	NOMINAL REYNOLD NUMBER	Nu. A Cold/Hot
65-96 (12mm flute 1,2m deep)	3,0	2,0	1,5	900	0,039
	6,0	2,0	1,5	900	0,880
	9,0	2,0	1,5	900	1,004
	12,0	2,0	1,5	900	0,983
	3,0	3,7	2,5	1 603	0,940
	6,0	3,7	2,5	1 630	1,047
	9,0	3,7	2,5	1 630	0,975
	12,0	3,7	2,5	1 630	1,042
	3,0	5,3	4,0	2 470	0,877
	6,0	5,3	4,0	2 470	1,047
	9,0	5,3	4,0	2 470	1,035
	12,0	5,3	4,0	2 470	1,053
	3,0	7,0	5,0	3 520	0,901
	6,0	7,0	5,0	3 520	1,034
	9,0	7,0	5,0	3 520	1,137
	12,0	7,0	5,0	3 520	1,236

Table J.3 Ratio of Nu.A cold/hot for corresponding flow situations.

Continued/...

TESTS 97-128 (19mm flute 0,6m deep)	NOMINAL WATER FLOW (kg/s)	NOMINAL AIR FLOW (kg/s)	NOMINAL AIR VELOCITY (m/s)	NOMINAL REYNOLD NUMBER	Nu. A Cold/Hot
	3,0	2,0	1,5	1 450	1,081
	6,0	2,0	1,5	1 450	1,027
	9,0	2,0	1,5	1 450	1,107
	12,0	2,0	1,5	1 450	1,079
	3,0	3,7	2,5	2 550	1,142
	6,0	3,7	2,5	2 550	1,033
	9,0	3,7	2,5	2 550	1,090
	12,0	3,7	2,5	2 550	1,092
	3,0	5,3	4,0	3 800	1,092
	6,0	5,3	4,0	3 800	1,003
	9,0	5,3	4,0	3 800	1,045
	12,0	5,3	4,0	3 800	1,049
	3,0	7,0	5,0	5 310	1,024
	6,0	7,0	5,0	5 310	0,974
	9,0	7,0	5,0	5 310	1,035
12,0	7,0	5,0	5 310	0,999	
					1,053 mean
TESTS 129-160 (19mm flute 1,2m deep)	NOMINAL WATER FLOW (kg/s)	NOMINAL AIR FLOW (kg/s)	NOMINAL AIR VELOCITY (m/s)	NOMINAL REYNOLD NUMBER	Nu. A Cold/Hot
	3,0	2,0	1,5	1 450	0,890
	6,0	2,0	1,5	1 450	1,061
	9,0	2,0	1,5	1 450	0,995
	12,0	2,0	1,5	1 450	1,098
	3,0	3,7	2,5	2 550	0,907
	6,0	3,7	2,5	2 550	1,051
	9,0	3,7	2,5	2 550	1,035
	12,0	3,7	2,5	2 550	0,998
	3,0	5,3	4,0	3 800	0,903
	6,0	5,3	4,0	3 800	1,036
	9,0	5,3	4,0	3 800	1,029
	12,0	5,3	4,0	3 800	0,974
	3,0	7,0	5,0	5 310	0,985
	6,0	7,0	5,0	5 310	1,081
	9,0	7,0	5,0	5 310	1,174
12,0	7,0	5,0	5 310	1,096	
					1,020 mean

Table J.3 Ratio of Nu.A cold/hot for corresponding flow situations.

		Temperature			
		0°C	10°C	40°C	50°C
Density	(kg/m <sup>3</sup> )	998	997	992	998
Viscosity	(Ns/m <sup>2</sup> )	1752	1300	651	544
Surface tension	(x10 <sup>-3</sup> Nm)	7,6	7,4	7,0	6,9

Note that the typical cold and hot water temperatures in the tests were 10°C and 40°C respectively.

Table J.4 Physical properties of water related to the formation of wet surface area

APPENDIX K ACCURACY OF MERKEL'S EQUATION WHEN USING  
SIGMA HEAT IN PLACE OF ENTHALPY

The exact equivalent of Merkel's equation when using sigma energy in place of enthalpy is given as:

$$\frac{q_1}{c_{p1}} = \left( \frac{h_c}{c_{p1} \Delta T} \right) [ \Sigma_w - \Sigma_{co} ] \quad (K.1)$$

In the same way that the accuracy of Merkel's equation was investigated in Section 6.4 the accuracy of this above equation has been examined.

The results are presented in the form of a correlation curve between the value of the sigma heat difference driving force and that of the true value as calculated from heat and mass transfer parameters. This plot is shown in Figure K.1 which gives an indication of the extent of the errors involved and their distribution (as a percentage of the true value). This figure should be compared to Figure 6.9 which is the equivalent figure used in the examination of the original Merkel equation. A close study will show that the sigma heat driving force equation is a slight improvement over the Merkel equation in terms of accuracy.




Figure K.1 Accuracy of Merkel's equation when using sigma energy in place of enthalpy (correlation and distribution of error)

APPENDIX L    PROCEDURE FOR CALCULATING  $\beta$  AND ITS VALUE  
FOR NON-SATURATED AIR CONDITIONS

The term,  $\beta$ , is defined for a specific set of conditions, through Equation 7.11, as:

$$\beta = \frac{c_{\text{avaf}} (t_w - t_{\text{db}} + \lambda B')}{(\Sigma_w - \Sigma_{\infty})} \quad (\text{L.1})$$

The value of  $\beta$  is dependant on the air condition, the water surface temperature and the barometric pressure. Because of the complexity of the form of the equations involved it is not possible to express the term as a simple analytical function. It is however simple to numerically calculate its value for a particular set of conditions and a short program listing specifying the procedure is given below.

Values of  $\beta$  for saturated air conditions are presented in the main text. Figures L.1 and L.2 below give values for non-saturated conditiors.




Figure L.1 Value of  $\beta$  for 50 per cent relative humidity air at 100 kPa




Figure L.2 Value of  $\beta$  for dry air at 100 kPa

```

10 ! PROGRAM - BETA
20 ! PROGRAM TO CALC VALUE OF B
   ETA
30 T1=30 ! Twater
40 T2=0 ! Tdb
50 T3=0 ! Twb
60 P=100 ! Pressure
70 T4=(T1+T2)/2 ! Tfilm
80 T5=(T1+T3)/2 ! Tfilm*
90 E1=.6105*EXP(17.27*T1/(237.3
+T1)) ! SAT VAP PRESS Tw
100 E3=.6105*EXP(17.27*T3/(237.3
+T3))
110 E2=(E3*(1555.6-2.465*T3+1.00
5*T2)-P*1.005*(T2-T3))/(1555
.6+1.139*T2-1.599*T3-E3*.14*(
T2-T3)/P)
120 ! VAP PRESS AIR
130 M1=.622*E1/(P-.378*E1) ! TSH
ws
140 M2=.622*E2/(P-.378*E2) ! TSH
air
150 L=2501-2.378*T1 ! LAT HEAT
160 E4=.6105*EXP(17.27*T4/(237.3
+T4)) ! SAT VAP PRESS FILM
170 E5=.6105*EXP(17.27*T5/(237.3
+T5)) ! SAT VAP PRESS FILM*
180 A4=.622*E4/(P-E4) ! FILM ASH
190 K=(2405+7.788*T4)*10^-5 ! FI
LM CONDUCTIVITY
200 D=1.676*10^-7*(T4+273.15)^1
694/P ! FILM DIFFUSIVITY
210 C=(1.005+1.84*A4)*(P-E4)/(P-
.378*E4) ! FILM Cp
220 R=(P-.378*E4)/(C*.287*(273.15+
T4)) ! FILM DENSITY
230 X=(C*1000*R*D/K)^(2/3) ! Lew
is No
240 B=LOG((1-M2)/(1-M1)) ! MASS
TRANS DRIVE FORCE
250 Q=X*LXB/C+T1-T2
260 A1=.622*E1/(P-E1) ! ASH Tw
270 A2=.622*E2/(P-E2) ! ASH AIR
280 S1=1.005*T1+(2501+1.84*T1)*R
1-4.187*A1*T1 ! SIGMA Tw
300 S2=1.005*T2+(2501+1.84*T2)*R
2-4.187*A2*T3 ! SIGMA air
320 A5=.622*E5/(P-E5) ! ASHfilm*
330 C5=1.005+1.84*A5 ! Cp film*
340 G=C5*Q/(S1-S2) ! BETA
350 PRINT "HEAT TRANSFER FROM WE
T SURFACE, VALUE OF BETA"
360 PRINT ""
370 PRINT "T dry bulb=";T2
380 PRINT "T wet bulb=";T3
390 PRINT "T water surface=";T1
400 PRINT "Ambient pressure=";P
410 PRINT "BETA =" ;G
430 PRINT ""
440 END

```

APPENDIX M Procedure for calculating the term  $\alpha$ , and its value for non-saturated conditions

The term,  $\alpha$ , for a differential element of direct-contact heat exchanger is defined by:

$$\frac{h}{\dot{Q}_a} = m_a \, di_a = \alpha \, m_a \, d\Sigma \quad (M.1)$$

The value of  $\alpha$  is dependant on the air condition, the water surface temperature and the barometric pressure. Because of the complexity of the form of the equations involved, it is not possible to express the term as a simple analytical function. It is however, a relatively simple matter to numerically calculate its value for a particular set of conditions. The short program listing given below specifies the exact procedure used.

Values of  $\alpha$  for saturated air conditions are presented in the main text. Figures M.1 and M.2 below give the values for non-saturated conditions at 100 kPa.




Figure M.1 Value of  $\alpha$  for 50 per cent relative humidity air at 100 kPa




Figure M.2 Value of  $\alpha$  for dry air at 100 kPa

```

10 ! PROGRAM - ALPHA
20 ! PROGRAM TO CALC ALPHA (WHE
   N FOG OCCURS AIR IS FORCED T
   O REMAIN SATURATED
30 T1=40 ! Twater
40 T2=50 ! Tdb
50 T3=17.902 ! Twb
60 P=100 ! Pressure
70 Y=10^-8 ! hcR/Ma
80 ! CALC OF HEAT @ MASS TRANS
90 T4=(T1+T2)/2 ! Tfilm
100 E1=.6105*EXP(17.27*T1/(237.3
   +T1)) ! SAT VAP PRESS AT Tw=
110 E9=.6105*EXP(17.27*T3/(237.3
   +T3))
120 E2=(E9*(1555.6-2.465*T3+1.00
   5*T2)-P*1.005*(T2-T3))/(1555
   .6+.139*T2-1.599*T3-E9*.14*(
   T2-T3)/P)
130 ! E2=VAP PRESS AIR
140 M1=.622*E1/(P-.378*E1) ! TSH
   WATER SURFACE

150 M2=.622*E2/(P-.378*E2) ! TSH
   AIR

160 L=2501-2.378*T1 ! LATENT HEA
   T
170 E4=.6105*EXP(17.27*T4/(237.3
   +T4)) ! VAP PRESS FILM
180 A4=.622*E4/(P-E4) ! ASH FILM
190 K=(2405+7.788*T4)*10^-5 ! CO
   NDUCTIVITY FILM

200 D=1.676*10^-7*(T4+273.15)^1.
   694/P ! DIFFUSIVITY FILM
210 C=(1.005+1.84*A4)*(P-E4)/(P-
   .378*E4) ! Cp FILM
220 R=(P-.378*E4)/(2.287*(273.15+
   T4)) ! DENSITY FILM
230 X=(C*1000*R*D/K)^(2/3) ! Lew
   is No
240 B=LOG((1-M2)/(1-M1)) ! MASS
   TRANS DRIVE FORCE
250 Q=X*L*B/C+T1-T2 ! TOTAL HEAT
   TRANS DRIVE FORCE
260 Z=Q*Y ! TOTAL ENERGY TRANS
270 ! CALC OF NEW CONDITIONS- NO
   SUPER SATURATION
280 A2=.622*E2/(P-E2) ! ASH BEFO
   RE

290 H2=1.005*T2+(2501+1.84*T2)*A
   2 ! ENTHALPY BEFORE
300 S2=H2-4.187*A2*T3 ! SIGMA BE
   FORE
310 IF T3=T2 THEN GOTO 470 ! FOG
   CREATED BY SAT CONDITIONS,
   THE AIR IS NOT ALLOWED TO FO
   G

```

```

320 H9=H2+Z ! ENTHALPY AFTER
330 A9=A2+Y*X*B/C ! ASH AFTER
340 T9=(H9-2501*A9)/(1.005+1.84*
A9) ! Tdb AFTER
350 E0=A9*P/(.622+A9) ! VAP PRES
S AFTER
360 Z9=T3 ! 1ST Twb GUESS
370 Z0= 6105*EXP(17.27*Z9/(237.3
+Z9)) ! SAT VAP PRESS AT Twb
380 Z7=(Z0*(1555.6-2.465*Z9+1.00
5*T9)-P*1.005*(T9-Z9))/(1555
6+.139*T9-1.599*Z9-Z0*.14*(
T9-Z9)/P)
390 ! Z7=VAP PRESS AS FUNC OF Tw
b
400 IF ABS(Z7-E0)<10^-10 THEN GO
TO 430
410 X1=Z8*4098/(237.3+Z9)^2+.064
! VAP PRESS;Twb DERIVITIVE
420 Z9=Z9-(Z7-E0)/X1 @ GOTO 370
430 S9=H9-4.187*A9*Z9 ! SIGMA AF
TET
440 " 2/(S9-S2) ! ALPHA
GOTO 530
460 ! CALC TO CATER FOR FOGGING
470 T=T2+ .0001 ! SMALL INCREASE
IN SAT TEMP

480 E= 6105*EXP(17.27*T/(237.3+T
))
490 A=.622*E/(P-E)
500 H=1.005*T+(2501+1.84*T)*A
510 S=H-4.187*A*T
520 U=(H2-H)/(S2-S) ! ALPHA
530 PRINT "HEAT TRANSFER FROM HE
T SURFACE"
540 PRINT "VALUE OF ALPHA"
550 PRINT ""
560 PRINT "T dry bulb=";T2
570 PRINT "T wet bulb=";T3
580 PRINT "T water surface=";T1
590 PRINT "Ambient pressure=";P
600 PRINT "ALPHA =" ;U
610 PRINT ""
620 END

```

**APPENDIX N Procedure for calculating the term,  $\gamma$ , and its value for non-saturated conditions**

Recall from the main text that  $\gamma$  is defined through the following equations:

$$\dot{q}_w = \dot{m}_{w1} c_w (t_{w1} - t_{wo}) + d\dot{m}_w c_w t_{w0} \quad (\text{N.1})$$

$$\dot{q}_w = \gamma \dot{m}_{w1} c_w (t_{w1} - t_{wo}) \quad (\text{N.2})$$

Combining these two equations gives:

$$\gamma = 1 + (\Delta\dot{m}_w / \dot{m}_{w1}) \cdot (t_{wo} / \Delta t_w) \quad (\text{N.3})$$

Note this equation applies irrespective of any fogging that may occur.

Alternatively, the formulations for the heat and mass transfer (from Chapter 2) may be substituted into Equation N.3 resulting in:

$$\gamma = 1 + \frac{B' c_w t_w}{(t_w - t_{db} + \lambda B' - c_w t_w B')} \quad (\text{N.4})$$

The value of this equation can be determined numerically from a knowledge of the air condition, barometric pressure and the water temperature. The routine used for this is listed below.

Values of this term for saturated conditions are given in the main text and values for non-saturated conditions at 100 kPa are given in Figures N.1 and N.2 below.




Figure N.1 Value of  $\gamma$  for 50 per cent relative humidity air at 100 kPa




Figure N.2 Value of  $\gamma$  for dry air at 100 kPa

```

10 ! PROGRAM GAMMA
20 ! PROGRAM TO CALC GAMMA, NOT
   EFFECTED BY FOGGING
30 T1=10 ! Twater
40 T2=30 ! Tdb
50 T3=30 ! Twb
60 A=1 ! Ma kg/s
70 W=1 ! Mw l/s
80 J=.001 ! hca/Ma
90 P=100 ! Pressure
100 H=J*A ! hca
110 T4=(T1+T2)/2 ! Tfilm
120 E1=.6105*EXP(17.27*T1/(237.3
   +T1)) ! SAT VAP PRESS AT Tws
130 E9=.6105*EXP(17.27*T3/(237.3
   +T3)) ! SAT VAP PRESS AT Twb
140 E2=(E9*(1555.6-2.465*T3+1.00
   5*T2)-P*1.005*(T2-T3))/(1555
   .6+1.139*T2-1.599*T3-E9*.14*(
   T2-T3)/P)
150 ! E2=VAP PRESS AIR IN
160 M1=.622*E1/(P-.378*E1) ! TSH
   ws
170 M2=.622*E2/(P-.378*E2) ! TSH
   air
180 L=2501-2.378*T1 ! LATENTHEAT
190 E4=.6105*EXP(17.27*T4/(237.3
   +T4)) ! FILM VAP PRESS
200 A4=.622*E4/(P-E4) ! FILM ASH
210 K=(2405+7.788*T4)*10^-5 ! Fi
   lm conductivity
220 D=1.676*10^-7*(T4+273.15)^1.
   694/P ! FILM DIFFUSIVITY
230 C=(1.005+1.84*A4)*(P-E4)/(P-
   378*E4) ! FILM Cp
240 R=(P-.378*E4)/(C.297*(273.15+
   T4)) ! FILM DENSITY
250 X=(C*1000*R*D/K)^(2/3) ! Le
260 B=LOG((1-M2)/(1-M1)) ! Mass
   trans drive force
270 Q=H*(X*L*B/C+T1-T2) ! TOTAL
   ENERGY TRANS
280 M=H*X*B/C ! MASS TRANS kg/s
290 B9=X*B/C ! B'=Mt/hca
300 T8=(W*T1-Q/4.187)/(W-M) ! Tw
   out
310 G=1+M*T1/(W*(T1-T8))
320 ! ALTERNATE METHOD
330 G1=1+B9*4.187*T1/(T1-T2+L*B9
   -B9*4.187*T1)
340 PRINT "HEAT TRANSFER FROM WE
   T SURFACE VALUE OF GAMMA"
360 PRINT "T dry bulb=";T2
370 PRINT "T wet bulb=";T3
380 PRINT "T water surface=";T1
390 PRINT "Ambient pressure=";P
400 PRINT "GAMMA";G;G1
430 END

```

APPENDIX O Mathematical manipulation to produce performance equation for direct-contact case

In the main text the following equation is developed.

$$\frac{h_c dA}{\dot{m}_a (\alpha/\beta) c_{avaf}^*} = \frac{dZ}{J_3 + J_4 Z} \quad (0.1)$$

where

$$J_3 = a + c_{aw}^* t_{wo} - \frac{\alpha_1}{\gamma_1} \frac{\dot{m}_a c_{aw}^*}{\dot{m}_w c_w} Z_1$$

$$J_4 = \frac{\alpha_1}{\gamma_1} \frac{\dot{m}_a c_{aw}^*}{\dot{m}_w c_w} - 1$$

This appendix details the mathematical manipulation required to solve this integral and to express the solution in a suitable form.

Integrating both sides of Equation 0.1 and using representative mean values of  $[(\alpha/\beta)c_{avaf}^*]$ ,  $c_{aw}^*$  and  $(\alpha/\gamma)_1$  produces:

$$\frac{h_c A}{\dot{m}_a (\alpha/\beta) c_{avaf}^*} = \frac{1}{J_4} [ \ln ( J_3 + J_4 Z_0 ) - \ln ( J_3 + J_4 Z_1 ) ] \quad (0.2)$$

which becomes:

$$\frac{J_3 + J_4 Z_0}{J_3 + J_4 Z_1} = e \left[ \frac{J_4 h_c A}{\dot{m}_a (\alpha/\beta) c_{avaf}^*} \right] \quad (0.3)$$

An overall heat balance across the heat exchanger produces (see Equation 7.49 Chapter 7):

$$\Sigma_0 = \Sigma_1 + \frac{\gamma_0}{\alpha_0} \frac{\dot{m}_w c_w}{\dot{m}_a} (t_{w1} - t_{w0}) \quad (0.4)$$

Substituting  $J_3$ ,  $J_4$  and  $\Sigma_0$  into Equation 0.3 produces the following for the numerator on the lefthand side:

$$\begin{aligned} a + c_{sw}^* t_{w0} - \frac{\alpha_1}{\gamma_1} \frac{\dot{m}_a c_w}{\dot{m}_w c_w} \Sigma_1 + \left[ \frac{\alpha_1}{\gamma_1} \frac{\dot{m}_a c_w}{\dot{m}_w c_w} - 1 \right] \left[ \Sigma_1 + \frac{\gamma_0}{\alpha_0} \frac{\dot{m}_w c_w}{\dot{m}_a} (t_{w1} - t_{w0}) \right] \\ - c_{sw}^* \left[ \frac{a}{c_{sw}^*} + t_{w0} - \frac{\Sigma_1}{c_{sw}^*} + \frac{\alpha_1}{\gamma_1} \frac{\gamma_0}{\alpha_0} (t_{w1} - t_{w0}) - \frac{\gamma_0}{\alpha_0} \frac{\dot{m}_w c_w}{\dot{m}_a c_w} (t_{w1} - t_{w0}) \right] \end{aligned} \quad (0.5)$$

Similarly, the denominator on the lefthand side becomes:

$$\begin{aligned} a + c_{sw}^* t_{w0} - \frac{\alpha_1}{\gamma_1} \frac{\dot{m}_a c_w}{\dot{m}_w c_w} \Sigma_1 + \frac{\alpha_1}{\gamma_1} \frac{\dot{m}_a c_w}{\dot{m}_w c_w} \Sigma_1 - \Sigma_1 \\ = a + c_{sw}^* t_{w0} - \Sigma_1 \end{aligned} \quad (0.6)$$

Equation 0.3 may then be written as:

$$\begin{aligned} a/c_{sw}^* + t_{w0} - \Sigma_1/c_{sw}^* + \frac{\alpha_1}{\gamma_1} \frac{\gamma_0}{\alpha_0} (t_{w1} - t_{w0}) - \frac{\gamma_0}{\alpha_0} \frac{\dot{m}_w c_w}{\dot{m}_a c_w} (t_{w1} - t_{w0}) \\ = \left( a/c_{sw}^* + t_{w0} - \Sigma_1/c_{sw}^* \right) \left[ \frac{J_4 h_c A}{\dot{m}_a c_w \alpha_0 (\alpha/\beta)} \right] \end{aligned} \quad (0.7)$$

Solving for  $t_{w0}$  gives:

$$t_{w0} = \frac{t_{w1} \left( \frac{\gamma_0}{\alpha_0} \frac{\dot{m}_w c_w}{\dot{m}_a c_w} - \frac{\alpha_1}{\gamma_1} \frac{\gamma_0}{\alpha_0} \right) + \left[ \left( \Sigma_1 - a \right) / c_{sw}^* \right] \left[ 1 - \left( \frac{J_4 h_c A}{\dot{m}_a c_w \alpha_0 (\alpha/\beta)} \right) \right]}{1 - \frac{\alpha_1}{\gamma_1} \frac{\gamma_0}{\alpha_0} + \frac{\gamma_0}{\alpha_0} \frac{\dot{m}_w c_w}{\dot{m}_a c_w} - \left( \frac{J_4 h_c A}{\dot{m}_a c_w \alpha_0 (\alpha/\beta)} \right)} \quad (0.8)$$

The water efficiency is given as:

$$\varepsilon_w = (t_{w1} - t_{w0}) / (t_{w1} - t_{a1}) \quad (0.9)$$

Substituting for  $t_{w0}$  gives:

$$E_w = \frac{(t_{w1} - (\Sigma_1 - a)/c_{aw}^*) [1 - e^{-\left(\frac{J_4 h_c A}{m_4 c_{aw}^* (\alpha/\beta)}\right)}]}{[t_{w1} - t_{w1}] \left[1 - \frac{\alpha_1}{\eta} \frac{\gamma_0}{\alpha_0} + \frac{\gamma_0}{\alpha_0} \frac{m_4 c_w}{m_4 c_{aw}^*} - e^{-\left(\frac{J_4 h_c A}{m_4 c_{aw}^* (\alpha/\beta)}\right)}\right]} \quad (0.10)$$

Substituting for  $J_4$  gives:

$$E_w = \frac{(t_{w1} - (\Sigma_1 - a)/c_{aw}^*) \left[1 - e^{-\left(\frac{h_c A}{m_4 c_{aw}^* (\alpha/\beta)}\right)}\right] \left(1 - \frac{\alpha_1}{\eta} \frac{m_4 c_w}{m_4 c_w}\right)}{[t_{w1} - t_{w1}] \left[1 - \frac{\alpha_1}{\eta} \frac{\gamma_0}{\alpha_0} + \frac{\gamma_0}{\alpha_0} \frac{m_4 c_w}{m_4 c_{aw}^*} - e^{-\left(\frac{h_c A}{m_4 c_{aw}^* (\alpha/\beta)}\right)}\right] \left(1 - \frac{\alpha_1}{\eta} \frac{m_4 c_w}{m_4 c_w}\right)} \quad (0.11)$$

Rearranging allows this to be written as:

$$\frac{t_{w1} - t_{w0}}{t_{w1} - (\Sigma_1 - a)/c_{aw}^*} = \frac{1 - e^{-\left(\frac{h_c A}{m_4 c_{aw}^* (\alpha/\beta)}\right)} \left(1 - \frac{\alpha_1}{\eta} \frac{m_4 c_w}{m_4 c_w}\right)}{\left[1 - \frac{\alpha_1}{\eta} \frac{\gamma_0}{\alpha_0} + \frac{\gamma_0}{\alpha_0} \frac{m_4 c_w}{m_4 c_{aw}^*} - e^{-\left(\frac{h_c A}{m_4 c_{aw}^* (\alpha/\beta)}\right)}\right] \left(1 - \frac{\alpha_1}{\eta} \frac{m_4 c_w}{m_4 c_w}\right)} \quad (0.12)$$

It must be noted that the lefthand side term can also be expressed as:

$$\frac{t_{w1} - t_{w0}}{t_{w1} - \frac{\Sigma_1 - a}{c_{aw}^*}} = \frac{t_{w1} - t_{w0}}{t_{w1} - \frac{c_{w1}^*}{c_{aw}^*} t_{a1}} \quad (0.13)$$

The term,  $c_{aw}^*$ , is the pseudo-specific heat term for saturated air at the air inlet condition.

Finally, the equation can be written in a simpler format by introducing various groupings of terms which, as discussed in the main text, are analogous to the so called

heat exchanger terms used for conventional heat exchangers  
(with the exception of the term,  $J$ ).

$$E_w = \frac{1 - e^{-N^*} (1 - 1/R^*)}{(1 - J + JR^*) - e^{-N^*} (1 - 1/R^*)} \quad (0.14)$$

where

$$R^* = [ \dot{m}_w c_w ] / [ \dot{m}_a c_{aw} (\alpha/\gamma)_1 ]$$

$$N^* = h_c A / [ \dot{m}_a (\alpha/\beta) c_{aw} ]$$

$$E_w = (t_{w1} - t_{w0}) / (t_{w1} - (\frac{c_{al}}{c_{aw}}) t_{w0})$$

$$J = (\alpha/\gamma)_1 / (\alpha/\gamma)_0$$

**APPENDIX P    Generation of simulated database.**

In order to supplement the experimental database a large number of test simulations were carried out. The computer simulator was run for a wide variety of flow conditions for heat exchangers with widely differing design characteristics over the full range of temperature conditions.

The heat and mass transfer conditions were simulated for water-air flow ratios of 0,75; 2,0 and 4,0; for a range of heat exchangers with design characteristic values of  $N^* = 1,0; 2,5$  and  $4,0$ ; for barometric pressures of 80; 100 and 120 kPa; and air and water inlet temperature conditions as shown in Table P.1. Unrealistic operating duties for water efficiencies less than 0,075 or greater than 0,925 were subsequently deleted from this set of data. This amounted to a total of more than 490 sets of conditions. This database is recorded in the following tables.

		Inlet water temperature (°C)										
		0	5	10	15	20	25	30	35	40	45	50
Inlet wet-bulb temperature (°C)	0											
	5				★		★		★		★	
	10											
	15		★				★		★		★	
	20											
	25		★		★				★		★	
	30											
	35		★		★		★				★	
	40											
	45		★		★		★		★			
	50											

Table P.1 Inlet temperature conditions used  
in generating simulated data base

	Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	h <sub>db</sub> W/°C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer g/s
80.01	.75	1.00	1.00	5.00	9.63	15.00	10.02	-14.79	-3.03	
80.01	.75	1.00	1.00	5.00	16.37	25.00	16.40	-36.37	-10.79	
80.01	.75	1.00	1.00	5.00	26.81	35.00	24.39	-60.39	-22.31	
80.01	.75	1.00	1.00	5.00	38.96	45.00	34.46	-112.97	-39.25	
80.01	.75	1.00	1.00	10.00	10.60	5.00	10.50	-13.01	3.23	
80.01	.75	1.00	1.00	10.00	21.23	25.00	20.64	-20.16	-6.22	
80.01	.75	1.00	1.00	10.00	30.95	35.00	27.94	-47.25	-16.41	
80.01	.75	1.00	1.00	10.00	41.53	45.00	37.21	-80.06	-31.52	
80.01	.75	1.00	1.00	20.00	15.15	5.00	16.24	-31.27	7.84	
80.01	.75	1.00	1.00	20.00	19.23	15.00	20.03	-18.39	5.21	
80.01	.75	1.00	1.00	20.00	33.00	35.00	31.53	-26.34	-9.80	
80.01	.75	1.00	1.00	20.00	43.26	45.00	39.97	-61.45	-22.50	
80.01	.75	1.00	1.00	35.00	10.56	5.00	21.70	-52.55	13.99	
80.01	.75	1.00	1.00	35.00	22.36	15.00	24.92	-40.68	11.96	
80.01	.75	1.00	1.00	35.00	27.67	25.00	29.21	-32.75	7.56	
80.01	.75	1.00	1.00	40.00	20.93	5.00	26.75	-77.36	21.66	
80.01	.75	1.00	1.00	40.00	24.49	15.00	29.47	-66.49	20.19	
80.01	.75	1.00	1.00	45.00	29.45	25.00	33.16	-50.60	16.46	
80.01	.75	1.00	1.00	45.00	36.26	35.00	38.21	-28.01	9.04	
100.01	.75	1.00	1.00	5.00	9.13	15.00	9.06	-13.15	-3.13	
100.01	.75	1.00	1.00	5.00	15.02	25.00	15.92	-31.94	-8.98	
100.01	.75	1.00	1.00	5.00	23.44	35.00	23.43	-60.60	-18.50	
100.01	.75	1.00	1.00	5.00	35.22	45.00	32.69	-99.02	-33.50	
100.01	.75	1.00	1.00	10.00	11.04	5.00	10.70	-12.42	2.63	
100.01	.75	1.00	1.00	10.00	20.51	25.00	20.37	-17.78	-5.16	
100.01	.75	1.00	1.00	10.00	28.36	35.00	27.21	-43.45	-13.79	
100.01	.75	1.00	1.00	10.00	39.03	45.00	35.00	-79.06	-27.24	
100.01	.75	1.00	1.00	20.00	16.14	5.00	14.56	-28.12	6.47	
100.01	.75	1.00	1.00	20.00	19.05	15.00	20.26	-16.43	4.35	
100.01	.75	1.00	1.00	20.00	32.19	35.00	31.12	-23.37	-7.60	
100.01	.75	1.00	1.00	20.00	41.02	45.00	38.97	-66.30	-19.78	
100.01	.75	1.00	1.00	30.00	20.15	5.00	22.32	-47.44	11.75	
100.01	.75	1.00	1.00	30.00	23.61	15.00	25.40	-36.61	10.16	
100.01	.75	1.00	1.00	30.00	28.30	25.00	29.50	-21.42	6.52	
100.01	.75	1.00	1.00	30.00	43.76	45.00	42.09	-29.32	-10.50	
100.01	.75	1.00	1.00	45.00	23.10	5.00	27.74	-70.45	10.56	
100.01	.75	1.00	1.00	45.00	26.33	15.00	30.41	-60.42	17.45	
100.01	.75	1.00	1.00	45.00	30.70	25.00	33.94	-46.39	14.46	
100.01	.75	1.00	1.00	45.00	36.96	35.00	38.60	-26.64	8.03	
120.01	.75	1.00	1.00	5.00	8.70	15.00	9.75	-12.02	-2.64	
120.01	.75	1.00	1.00	5.00	14.06	25.00	15.59	-20.03	-7.54	
120.01	.75	1.00	1.00	5.00	21.56	35.00	22.76	-33.36	-15.06	
120.01	.75	1.00	1.00	5.00	32.15	45.00	31.50	-89.25	-29.05	
120.01	.75	1.00	1.00	10.00	11.35	5.00	10.77	-11.45	2.22	
120.01	.75	1.00	1.00	10.00	19.90	25.00	20.10	-16.96	-4.46	
120.01	.75	1.00	1.00	10.00	27.04	35.00	28.69	-39.10	-11.00	
120.01	.75	1.00	1.00	10.00	36.01	45.00	34.79	-72.23	-23.76	
120.01	.75	1.00	1.00	20.00	16.05	5.00	14.76	-25.02	5.49	
120.01	.75	1.00	1.00	20.00	29.31	15.00	20.44	-15.04	3.74	
120.01	.75	1.00	1.00	20.00	31.34	35.00	30.02	-21.42	-6.00	

Table P.2 Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer g/s	
126.01	.75	1.00	1.00	25.00	40.40	45.00	38.24	-51.57	-17.51
126.01	.75	1.00	1.00	35.00	21.36	5.00	22.75	43.73	10.12
126.01	.75	1.00	1.00	35.00	24.59	15.00	25.88	33.81	8.02
126.01	.75	1.00	1.00	35.00	28.96	25.00	29.85	19.66	5.73
126.01	.75	1.00	1.00	35.00	43.16	45.00	41.69	-27.35	-9.57
126.01	.75	1.00	1.00	45.00	24.70	5.00	26.43	45.17	16.22
126.01	.75	1.00	1.00	45.00	27.00	15.00	31.11	55.79	15.30
126.01	.75	1.00	1.00	45.00	31.80	25.00	34.53	42.91	12.00
126.01	.75	1.00	1.00	45.00	37.40	35.00	39.04	24.85	7.99
86.01	.75	1.00	2.50	5.00	11.60	15.00	7.91	-21.23	-5.41
86.01	.75	1.00	2.50	5.00	21.01	25.00	11.90	-51.30	-14.05
86.01	.75	1.00	2.50	15.00	8.72	5.00	12.79	19.80	4.77
86.01	.75	1.00	2.50	15.00	23.56	25.00	18.77	-27.79	-0.44
86.01	.75	1.00	2.50	25.00	11.20	5.00	19.63	45.80	11.43
86.01	.75	1.00	2.50	25.00	17.09	15.00	21.68	25.34	7.20
86.01	.75	1.00	2.50	35.00	12.66	5.00	25.59	71.21	19.73
86.01	.75	1.00	2.50	35.00	18.26	15.00	27.35	53.79	16.09
86.01	.75	1.00	2.50	45.00	18.07	15.00	32.10	84.12	25.90
106.01	.75	1.00	2.50	5.00	10.99	15.00	7.22	-19.83	-4.43
106.01	.75	1.00	2.50	5.00	19.33	25.00	10.60	-45.99	-12.29
106.01	.75	1.00	2.50	5.00	30.71	35.00	16.34	-35.21	-25.27
106.01	.75	1.00	2.50	15.00	9.30	5.00	12.95	18.05	3.95
106.01	.75	1.00	2.50	15.00	22.70	25.00	18.17	-25.11	-7.10
106.01	.75	1.00	2.50	15.00	33.04	35.00	23.35	-39.23	-10.57
106.01	.75	1.00	2.50	25.00	12.39	5.00	20.29	46.11	9.69
106.01	.75	1.00	2.50	25.00	17.77	15.00	22.14	23.18	6.24
106.01	.75	1.00	2.50	35.00	14.36	5.00	26.75	45.86	17.17
106.01	.75	1.00	2.50	35.00	19.46	15.00	20.37	49.93	14.20
106.01	.75	1.00	2.50	35.00	26.27	25.00	30.00	28.37	8.69
106.01	.75	1.00	2.50	45.00	15.40	5.00	32.26	94.30	26.05
106.01	.75	1.00	2.50	45.00	20.41	15.00	33.66	79.24	23.45
106.01	.75	1.00	2.50	45.00	26.98	25.00	35.82	58.70	18.51
126.01	.75	1.00	2.50	5.00	10.51	15.00	7.05	-17.46	-3.74
126.01	.75	1.00	2.50	5.00	18.06	25.00	10.01	-41.00	-10.43
126.01	.75	1.00	2.50	5.00	20.52	35.00	14.75	-76.46	-21.74
126.01	.75	1.00	2.50	5.00	41.91	45.00	23.26	-122.71	-30.00
126.01	.75	1.00	2.50	15.00	9.72	5.00	13.11	16.71	3.36
126.01	.75	1.00	2.50	15.00	22.14	25.00	17.79	-22.99	-6.19
126.01	.75	1.00	2.50	15.00	31.70	35.00	22.30	-34.00	-16.37
126.01	.75	1.00	2.50	25.00	13.30	5.00	20.73	37.21	8.30
126.01	.75	1.00	2.50	25.00	18.31	15.00	22.45	21.43	5.44
126.01	.75	1.00	2.50	25.00	33.04	35.00	20.13	-20.00	-7.10
126.01	.75	1.00	2.50	35.00	15.72	5.00	27.57	61.33	15.13
126.01	.75	1.00	2.50	35.00	20.40	15.00	29.10	46.00	12.63
126.01	.75	1.00	2.50	35.00	26.70	25.00	31.37	26.70	7.06
126.01	.75	1.00	2.50	45.00	17.20	5.00	33.50	88.90	23.43
126.01	.75	1.00	2.50	45.00	21.77	15.00	34.83	74.09	21.30
126.01	.75	1.00	2.50	45.00	27.70	25.00	36.00	56.00	17.00
86.01	.75	1.00	4.00	5.00	12.47	15.00	6.45	-23.76	-5.99
86.01	.75	1.00	4.00	5.00	22.76	25.00	9.40	-57.33	-16.31

Table P.2 (Cont) Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	ACA W/°C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Heat kW	Mass transfer g/s
88.01	0.75	1.00	4.00	15.00	7.96	5.00	13.49	22.29	5.48
88.01	0.75	1.00	4.00	25.00	9.61	5.00	20.84	48.85	12.89
88.01	0.75	1.00	4.00	25.00	16.29	15.00	22.25	27.91	8.64
88.01	0.75	1.00	4.00	35.00	14.40	5.00	26.88	78.21	21.94
88.01	0.75	1.00	4.00	35.00	16.86	15.00	28.12	58.28	17.51
88.01	0.75	1.00	4.00	45.00	14.72	5.00	31.80	189.87	31.96
100.01	0.75	1.00	4.00	5.00	11.67	15.00	6.16	-21.26	-4.89
100.01	0.75	1.00	4.00	5.00	28.99	25.00	8.24	-51.39	-13.51
100.01	0.75	1.00	4.00	15.00	8.69	5.00	13.78	28.25	4.49
100.01	0.75	1.00	4.00	15.00	23.65	25.00	17.26	-27.95	-7.92
100.01	0.75	1.00	4.00	25.00	18.85	5.00	21.64	44.94	11.44
100.01	0.75	1.00	4.00	25.00	16.93	15.00	22.83	25.82	7.88
100.01	0.75	1.00	4.00	35.00	12.84	5.00	28.28	73.68	19.37
100.01	0.75	1.00	4.00	35.00	17.90	15.00	29.36	54.88	15.72
100.01	0.75	1.00	4.00	45.00	12.89	5.00	33.74	183.31	28.93
100.01	0.75	1.00	4.00	45.00	18.33	15.00	34.88	85.78	25.55
120.01	0.75	1.00	4.00	5.00	11.14	15.00	6.89	-19.44	-4.18
120.01	0.75	1.00	4.00	5.00	19.57	25.00	7.62	-46.65	-11.41
120.01	0.75	1.00	4.00	5.00	31.14	35.00	18.94	-85.31	-23.71
120.01	0.75	1.00	4.00	15.00	9.87	5.00	13.93	18.65	3.88
120.01	0.75	1.00	4.00	15.00	22.99	25.00	16.79	-25.71	-6.85
120.01	0.75	1.00	4.00	15.00	33.48	35.00	26.32	-68.85	-17.89
120.01	0.75	1.00	4.00	25.00	11.83	5.00	22.14	41.73	9.58
120.01	0.75	1.00	4.00	25.00	17.49	15.00	23.18	23.89	6.11
120.01	0.75	1.00	4.00	35.00	13.42	5.00	29.27	68.79	17.27
120.01	0.75	1.00	4.00	35.00	18.86	15.00	36.22	51.67	14.13
120.01	0.75	1.00	4.00	35.00	26.80	25.00	31.80	29.18	8.61
120.01	0.75	1.00	4.00	45.00	14.21	5.00	35.17	98.89	26.32
120.01	0.75	1.00	4.00	45.00	19.53	15.00	36.84	81.79	23.49
170.01	2.00	1.00	1.00	5.00	4.95	15.00	9.35	-16.58	-4.27
88.01	2.00	1.00	1.00	5.00	9.93	25.00	14.98	-41.42	-12.18
88.01	2.00	1.00	1.00	5.00	14.44	35.00	21.81	-84.48	-26.89
88.01	2.00	1.00	1.00	5.00	21.51	45.00	38.25	-143.82	-49.25
88.01	2.00	1.00	1.00	15.00	13.87	5.00	11.36	15.98	3.77
88.01	2.00	1.00	1.00	15.00	17.79	25.00	19.66	-24.19	-7.39
88.01	2.00	1.00	1.00	15.00	22.11	35.00	25.69	-61.74	-28.24
88.01	2.00	1.00	1.00	15.00	28.87	45.00	33.35	-121.11	-42.64
88.01	2.00	1.00	1.00	25.00	28.49	5.00	18.18	38.25	9.88
88.01	2.00	1.00	1.00	25.00	22.38	15.00	21.18	22.88	6.53
88.01	2.00	1.00	1.00	25.00	29.85	35.00	38.15	-35.67	-12.16
88.01	2.00	1.00	1.00	25.00	35.31	45.00	34.92	-71.95	-32.66
88.01	2.00	1.00	1.00	35.00	28.97	5.00	25.17	67.83	19.84
88.01	2.00	1.00	1.00	35.00	28.67	15.00	27.49	54.57	16.34
88.01	2.00	1.00	1.00	35.00	31.19	25.00	38.66	33.86	18.68
88.01	2.00	1.00	1.00	35.00	48.78	45.00	48.89	-51.42	-18.82
88.01	2.00	1.00	1.00	45.00	32.58	5.00	31.98	118.35	32.38
88.01	2.00	1.00	1.00	45.00	33.89	15.00	33.82	98.97	38.27
88.01	2.00	1.00	1.00	45.00	34.22	25.00	36.37	77.83	25.34
88.01	2.00	1.00	1.00	45.00	39.72	35.00	39.96	46.56	15.98
100.01	2.00	1.00	1.00	5.00	6.71	15.00	9.27	-14.51	-3.43

Table P.2 (Cont) Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	h <sub>in</sub> W/C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer g/s
186.81	2.86	1.00	1.00	5.60	9.25	25.00	14.63	-35.62	-9.81
186.81	2.86	1.00	1.00	5.60	13.41	35.00	21.26	-67.89	-26.92
186.81	2.86	1.00	1.00	5.60	18.76	45.00	29.39	-118.54	-39.46
186.81	2.86	1.00	1.00	15.00	13.33	5.00	11.41	14.15	-3.93
186.81	2.86	1.00	1.00	15.00	17.38	25.00	19.52	-29.68	-5.93
186.81	2.86	1.00	1.00	15.00	21.05	35.00	25.33	-51.05	-16.28
186.81	2.86	1.00	1.00	15.00	26.55	45.00	32.55	-100.65	-33.83
186.81	2.86	1.00	1.00	25.00	21.07	5.00	18.28	33.43	7.87
186.81	2.86	1.00	1.00	25.00	22.69	15.00	21.22	19.89	5.29
186.81	2.86	1.00	1.00	25.00	26.46	35.00	29.95	-29.91	-9.78
186.81	2.86	1.00	1.00	25.00	33.88	45.00	36.33	-76.21	-26.28
186.81	2.86	1.00	1.00	35.00	28.84	5.00	25.42	59.98	15.49
186.81	2.86	1.00	1.00	35.00	29.57	15.00	27.77	47.41	13.29
186.81	2.86	1.00	1.00	35.00	31.73	25.00	30.83	28.11	8.61
186.81	2.86	1.00	1.00	35.00	39.89	45.00	46.54	-43.31	-15.48
186.81	2.86	1.00	1.00	45.00	33.98	5.00	32.49	95.74	26.49
186.81	2.86	1.00	1.00	45.00	35.42	15.00	34.35	83.62	24.84
186.81	2.86	1.00	1.00	45.00	37.46	25.00	36.84	66.84	20.99
186.81	2.86	1.00	1.00	45.00	48.48	35.00	48.27	-39.78	-13.25
126.81	2.86	1.00	1.00	5.60	8.55	15.00	9.22	-13.12	-2.87
126.81	2.86	1.00	1.00	5.60	8.72	25.00	14.39	-14.39	-8.24
126.81	2.86	1.00	1.00	5.60	12.02	35.00	20.83	-59.59	-17.55
126.81	2.86	1.00	1.00	5.60	16.96	45.00	28.61	-102.33	-32.98
126.81	2.86	1.00	1.00	15.00	13.48	5.00	11.42	12.85	2.52
126.81	2.86	1.00	1.00	15.00	17.11	25.00	19.43	-18.38	-4.94
126.81	2.86	1.00	1.00	15.00	20.29	35.00	25.65	-46.33	-13.65
126.81	2.86	1.00	1.00	15.00	25.01	45.00	32.06	-86.82	-28.31
126.81	2.86	1.00	1.00	25.00	21.48	5.00	18.33	38.13	6.36
126.81	2.86	1.00	1.00	25.00	22.94	15.00	21.28	17.65	4.42
126.81	2.86	1.00	1.00	25.00	28.89	35.00	29.78	-26.17	-8.22
126.81	2.86	1.00	1.00	25.00	32.55	45.00	35.93	-65.78	-21.94
126.81	2.86	1.00	1.00	35.00	28.78	5.00	25.62	53.85	12.85
126.81	2.86	1.00	1.00	35.00	30.17	15.00	27.91	41.65	11.15
126.81	2.86	1.00	1.00	35.00	32.12	25.00	30.96	24.75	7.28
126.81	2.86	1.00	1.00	35.00	39.26	45.00	48.38	-37.54	-12.99
126.81	2.86	1.00	1.00	45.00	35.17	5.00	32.79	85.32	22.32
126.81	2.86	1.00	1.00	45.00	36.59	15.00	34.68	74.05	21.83
126.81	2.86	1.00	1.00	45.00	38.35	25.00	37.15	58.19	17.75
126.81	2.86	1.00	1.00	45.00	41.82	35.00	48.48	-34.08	-11.28
86.81	2.86	1.00	2.50	5.60	7.85	15.00	6.34	-24.83	-6.84
86.81	2.86	1.00	2.50	5.60	12.67	25.00	8.26	-60.46	-17.84
86.81	2.86	1.00	2.50	5.60	18.87	35.00	11.33	-117.68	-36.39
86.81	2.86	1.00	2.50	5.60	29.83	45.00	16.34	-289.98	-69.82
86.81	2.86	1.00	2.50	15.00	12.28	5.00	13.83	23.34	5.68
86.81	2.86	1.00	2.50	15.00	19.18	25.00	16.68	-35.39	-10.68
86.81	2.86	1.00	2.50	15.00	25.45	35.00	19.41	-100.59	-29.89
86.81	2.86	1.00	2.50	15.00	35.25	45.00	24.83	-178.17	-60.65
86.81	2.86	1.00	2.50	25.00	18.39	5.00	22.52	56.23	15.18
86.81	2.86	1.00	2.50	25.00	21.84	15.00	23.48	33.61	9.78
86.81	2.86	1.00	2.50	25.00	36.96	35.00	27.41	-52.37	-17.52

Table P.2 (Cont) Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	h <sub>ex</sub> W/C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer g/s
80.01	2.00	1.00	2.50	25.00	39.98	45.00	31.66	-133.57	-46.79
80.01	2.00	1.00	2.50	35.00	23.19	5.00	38.67	181.33	29.41
80.01	2.00	1.00	2.50	35.00	25.72	15.00	31.92	86.09	24.62
80.01	2.00	1.00	2.50	35.00	29.43	25.00	32.82	48.24	15.62
80.01	2.00	1.00	2.50	35.00	43.18	45.00	38.85	-73.85	-26.29
80.01	2.00	1.00	2.50	45.00	26.52	5.00	37.96	159.84	49.13
80.01	2.00	1.00	2.50	45.00	28.91	15.00	38.89	139.88	44.90
80.01	2.00	1.00	2.50	45.00	32.37	25.00	39.91	119.33	36.81
80.01	2.00	1.00	2.50	45.00	37.54	35.00	41.68	65.71	22.67
100.01	2.00	1.00	2.50	5.00	7.51	15.00	6.26	-21.93	-4.83
100.01	2.00	1.00	2.50	5.00	11.10	25.00	8.82	-31.87	-13.59
100.01	2.00	1.00	2.50	5.00	16.56	35.00	16.76	-99.06	-28.93
100.01	2.00	1.50	2.50	5.00	25.01	45.00	14.86	-173.49	-55.19
100.01	2.00	1.00	2.50	15.00	12.33	5.00	13.90	28.57	4.56
100.01	2.00	1.00	2.50	15.00	16.51	25.00	16.32	-38.19	-8.49
100.01	2.00	1.00	2.50	15.00	23.84	35.00	19.89	-76.93	-23.23
100.01	2.00	1.00	2.50	15.00	31.93	45.00	22.61	-148.16	-48.38
100.01	2.00	1.00	2.50	25.00	19.22	5.00	22.73	49.81	12.20
100.01	2.00	1.00	2.50	25.00	21.50	15.00	23.44	29.41	7.92
100.01	2.00	1.00	2.50	25.00	30.65	35.00	27.84	-44.27	-14.18
100.01	2.00	1.00	2.50	25.00	37.69	45.00	30.43	-112.66	-38.64
100.01	2.00	1.00	2.50	35.00	24.71	5.00	31.18	86.22	24.89
100.01	2.00	1.00	2.50	35.00	26.98	15.00	31.98	69.13	20.21
100.01	2.00	1.00	2.50	35.00	36.28	25.00	33.13	41.40	12.65
100.01	2.00	1.00	2.50	35.00	42.11	45.00	38.11	-63.15	-22.81
100.01	2.00	1.00	2.50	45.00	28.81	5.00	38.95	148.26	41.12
100.01	2.00	1.00	2.50	45.00	30.93	15.00	39.63	122.29	37.68
100.01	2.00	1.00	2.50	45.00	34.80	25.00	46.67	96.42	31.89
100.01	2.00	1.00	2.50	45.00	38.46	35.00	42.25	37.56	19.38
120.01	2.00	1.00	2.50	5.00	7.28	15.00	6.23	-19.81	-4.82
120.01	2.00	1.00	2.50	5.00	16.45	25.00	7.88	-46.15	-11.36
120.01	2.00	1.00	2.50	5.00	15.16	35.00	18.38	-86.78	-24.62
120.01	2.00	1.00	2.50	5.00	22.32	45.00	13.96	-149.43	-45.58
120.01	2.00	1.00	2.50	15.00	12.75	5.00	13.93	18.67	3.88
120.01	2.00	1.00	2.50	15.00	18.11	25.00	16.42	-26.69	-7.88
120.01	2.00	1.00	2.50	15.00	22.74	35.00	18.57	-66.31	-19.31
120.01	2.00	1.00	2.50	15.00	29.66	45.00	21.79	-127.61	-48.13
120.01	2.00	1.00	2.50	25.00	19.79	5.00	22.86	44.10	18.22
120.01	2.00	1.00	2.50	25.00	21.94	15.00	23.73	25.79	6.63
120.01	2.00	1.00	2.50	25.00	29.41	35.00	26.82	-38.62	-11.88
120.01	2.00	1.00	2.50	25.00	36.87	45.00	29.78	-97.24	-31.76
120.01	2.00	1.00	2.50	35.00	25.79	5.00	31.58	78.96	28.36
120.01	2.00	1.00	2.50	35.00	27.87	15.00	32.27	61.42	17.18
120.01	2.00	1.00	2.50	35.00	30.77	25.00	33.35	36.88	18.99
120.01	2.00	1.00	2.50	35.00	41.25	45.00	37.65	-35.32	-18.73
120.01	2.00	1.00	2.50	45.00	36.48	5.00	39.59	128.72	35.22
120.01	2.00	1.00	2.50	45.00	32.46	15.00	40.25	189.83	32.33
120.01	2.00	1.00	2.50	45.00	35.21	25.00	41.19	85.56	26.78
120.01	2.00	1.00	2.50	45.00	39.19	35.00	42.66	31.35	16.76
80.01	2.00	1.00	4.00	5.00	8.11	15.00	5.43	-26.11	-6.49

Table P.2 (Cont) Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	h <sub>ea</sub> W/°C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass G g/s
100.01	4.00	1.00	4.00	3.00	9.48	23.00	5.60	-56.00	-14.62
100.01	4.00	1.50	4.00	3.00	11.42	35.00	6.23	-100.91	-31.09
100.01	4.00	1.00	4.00	3.00	14.21	45.00	7.17	-192.22	-39.53
100.01	4.00	1.00	4.00	13.00	13.41	23.00	14.74	22.06	5.13
100.01	4.00	1.00	4.00	13.00	16.76	22.00	15.31	35.69	-7.36
100.01	4.00	1.00	4.00	13.00	19.99	35.00	15.84	-65.43	-25.69
100.01	4.00	1.00	4.00	13.00	24.72	45.00	16.68	-160.23	-53.91
100.01	4.00	1.00	4.00	25.00	21.70	5.00	24.50	56.06	14.25
100.01	4.00	1.00	4.00	25.00	23.43	15.00	24.67	33.21	9.15
100.01	4.00	1.00	4.00	25.00	27.94	35.00	25.43	-51.35	-16.21
100.01	4.00	1.00	4.00	25.00	32.60	43.00	26.27	-133.05	-44.09
100.01	4.00	1.00	4.00	35.00	28.08	5.00	34.05	105.30	29.57
100.01	4.00	1.00	4.00	35.00	30.19	15.00	34.24	82.90	21.64
100.01	4.00	1.00	4.00	35.00	32.07	25.00	34.51	50.00	15.66
100.01	4.00	1.00	4.00	35.00	39.52	45.00	35.00	-79.09	-27.30
100.01	4.00	1.00	4.00	45.00	34.76	5.00	43.24	170.53	54.14
100.01	4.00	1.00	4.00	45.00	36.84	15.00	43.43	156.79	49.46
100.01	4.00	1.00	4.00	45.00	37.09	25.00	43.71	125.04	40.00
100.01	4.00	1.00	4.00	45.00	40.66	35.00	44.14	76.33	25.76
120.01	4.00	1.00	4.00	5.00	8.26	15.00	5.20	-20.77	-4.33
120.01	4.00	1.00	4.00	5.00	8.43	25.00	5.65	-64.41	-12.11
120.01	4.00	1.00	4.00	5.00	10.62	35.00	6.16	-94.96	-25.64
120.01	4.00	1.00	4.00	5.00	14.62	45.00	6.97	-164.46	-40.74
120.01	4.00	1.00	4.00	15.00	13.74	5.00	14.75	20.67	4.27
120.01	4.00	1.00	4.00	15.00	16.73	25.00	15.30	-29.67	-7.74
120.01	4.00	1.00	4.00	15.00	19.27	35.00	15.71	-74.03	-21.21
120.01	4.00	1.00	4.00	15.00	23.30	45.00	16.50	-143.01	-44.11
120.01	4.00	1.00	4.00	25.00	22.04	5.00	24.31	49.02	11.00
120.01	4.00	1.00	4.00	25.00	23.26	15.00	24.70	29.23	7.39
120.01	4.00	1.00	4.00	25.00	27.50	35.00	25.36	-44.20	-13.39
120.01	4.00	1.00	4.00	25.00	31.46	45.00	26.09	-112.49	-36.06
120.01	4.00	1.00	4.00	35.00	29.62	5.00	34.17	92.05	24.57
120.01	4.00	1.00	4.00	35.00	30.00	15.00	34.33	72.13	20.43
120.01	4.00	1.00	4.00	35.00	32.49	25.00	34.50	43.30	12.97
120.01	4.00	1.00	4.00	35.00	30.79	45.00	35.60	-67.15	-22.47
120.01	4.00	1.00	4.00	45.00	30.07	5.00	43.05	105.71	45.19
120.01	4.00	1.00	4.00	45.00	37.25	15.00	43.71	135.79	41.24
120.01	4.00	1.00	4.00	45.00	30.00	25.00	43.95	107.47	34.02
120.01	4.00	1.00	4.00	43.00	41.29	35.00	44.32	65.10	21.30

Table P.2 (Cont) Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer g/s	
105.01	4.00	1.00	2.50	25.00	31.91	45.00	28.73	-121.45	-48.70
105.01	4.00	1.00	2.50	35.00	29.45	5.00	32.44	95.42	26.39
105.01	4.00	1.00	2.50	35.00	30.65	15.00	32.99	75.18	22.12
105.01	4.00	1.00	2.50	35.00	32.37	25.00	33.76	45.28	14.18
105.01	4.00	1.00	2.50	35.00	34.95	35.00	36.91	-72.97	-24.92
105.01	4.00	1.00	2.50	45.00	35.88	35.00	41.18	157.14	47.51
105.01	4.00	1.00	2.50	45.00	37.82	15.00	41.63	139.64	43.99
105.01	4.00	1.00	2.50	45.00	38.67	25.00	42.38	111.23	36.14
105.01	4.00	1.00	2.50	45.00	41.16	35.00	43.33	68.88	22.83
105.01	4.00	1.00	2.50	5.00	6.17	15.00	6.83	-19.38	-4.89
120.01	4.00	1.00	2.50	3.00	7.81	25.00	7.43	-47.82	-11.47
120.01	4.00	1.00	2.50	3.00	19.21	35.00	9.43	-80.52	-24.38
120.01	4.00	1.00	2.50	5.00	13.96	45.00	12.44	-153.81	-46.38
120.01	4.00	1.00	2.50	15.00	13.84	5.00	14.15	19.28	3.93
120.01	4.00	1.00	2.50	15.00	16.61	25.00	16.14	-27.42	-7.25
120.01	4.00	1.00	2.50	15.00	18.97	35.00	17.76	-68.57	-19.88
120.01	4.00	1.00	2.50	15.00	22.67	45.00	19.28	-132.33	-41.38
120.01	4.00	1.00	2.50	25.00	22.29	5.00	22.48	45.94	18.73
120.01	4.00	1.00	2.50	25.00	23.39	15.00	24.84	28.88	6.93
120.01	4.00	1.00	2.50	25.00	27.32	35.00	26.34	-46.49	-12.45
120.01	4.00	1.00	2.50	25.00	35.99	45.00	28.41	-183.17	-35.48
120.01	4.00	1.00	2.50	35.00	38.18	5.00	32.58	84.25	21.98
120.01	4.00	1.00	2.50	35.00	31.19	15.00	33.12	65.73	18.43
120.01	4.00	1.00	2.50	35.00	32.71	25.00	33.86	39.26	11.74
120.01	4.00	1.50	2.50	35.00	38.47	45.00	36.75	-68.88	-28.44
120.01	4.00	1.00	2.50	45.00	37.88	5.00	41.58	139.51	39.78
120.01	4.00	1.00	2.50	45.00	38.95	15.00	41.43	121.51	36.46
120.01	4.00	1.00	2.50	45.00	39.52	25.00	42.56	96.88	36.26
120.01	4.00	1.00	2.50	45.00	41.68	35.00	43.49	58.89	19.82
80.01	4.00	1.00	4.00	5.00	6.59	15.00	5.38	-26.41	-6.35
80.01	4.00	1.00	4.00	5.00	8.97	25.00	5.72	-66.53	-18.44
80.01	4.00	1.00	4.00	5.00	12.46	35.00	6.36	-138.57	-39.48
80.01	4.00	1.00	4.00	5.00	18.48	45.00	7.58	-235.72	-74.45
80.01	4.00	1.00	4.00	15.00	13.41	5.00	14.72	26.18	6.44
80.01	4.00	1.00	4.00	15.00	17.32	25.00	18.34	-39.96	-11.82
80.01	4.00	1.00	4.00	15.00	21.81	35.00	15.96	-183.28	-32.64
80.01	4.00	1.00	4.00	15.00	26.91	45.00	16.98	-287.72	-69.28
80.01	4.00	1.00	4.00	25.00	21.16	5.00	24.42	65.27	17.87
80.01	4.00	1.00	4.00	25.00	22.69	15.00	24.65	39.51	11.54
80.01	4.00	1.00	4.00	25.00	28.57	35.00	25.54	-62.53	-28.68
80.01	4.00	1.00	4.00	25.00	34.38	45.00	26.68	-164.93	-56.57
80.01	4.00	1.00	4.00	35.00	27.88	5.00	35.99	124.89	37.17
80.01	4.00	1.00	4.00	35.00	29.27	15.00	34.88	98.99	38.95
80.01	4.00	1.00	4.00	35.00	31.56	25.00	34.48	66.46	19.72
80.01	4.00	1.00	4.00	35.00	48.58	45.00	36.89	-98.86	-34.81
80.01	4.00	1.00	4.00	45.00	32.85	5.00	42.76	212.16	67.35
80.01	4.00	1.00	4.00	45.00	34.28	15.00	42.95	187.56	61.54
80.01	4.00	1.00	4.00	45.00	36.43	25.00	43.38	158.73	58.95
80.01	4.00	1.00	4.00	45.00	39.74	35.00	43.85	92.73	32.17
100.01	4.00	1.00	4.00	5.00	8.48	15.00	5.29	-25.82	-6.22

Table P.2 (Cont) Simulated database

	Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	b/a W/°C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer g/s
120.0	4.00	1.00	1.00	5.00	6.92	25.00	14.86	-32.62	-8.43	
120.01	4.00	1.00	1.00	5.00	6.57	33.00	20.26	-61.33	-10.00	
120.02	4.00	1.00	1.00	5.00	11.22	45.00	27.84	-105.53	-33.93	
120.03	4.00	1.00	1.00	15.00	14.20	5.00	11.60	13.26	2.61	
120.04	4.00	1.00	1.00	15.00	16.11	25.00	19.23	-18.98	-5.11	
120.05	4.00	1.00	1.00	15.00	17.73	35.00	24.58	-47.12	-14.15	
120.06	4.00	1.00	1.00	15.00	20.26	45.00	31.23	-99.32	-29.44	
120.07	4.00	1.00	1.00	25.00	23.12	5.00	10.78	31.43	6.09	
120.08	4.00	1.00	1.00	25.00	23.69	15.00	21.52	18.43	4.53	
120.09	4.00	1.00	1.00	25.00	26.66	35.00	29.48	-27.51	-6.61	
120.10	4.00	1.00	1.00	25.00	29.64	45.00	35.23	-69.75	-23.14	
120.11	4.00	1.00	1.00	35.00	31.65	5.00	24.46	57.11	13.07	
120.12	4.00	1.00	1.00	35.00	32.46	15.00	28.09	44.40	11.98	
120.13	4.00	1.00	1.00	35.00	35.45	25.00	31.34	26.58	7.82	
120.14	4.00	1.00	1.00	35.00	37.34	45.00	39.84	-46.77	-14.85	
120.15	4.00	1.00	1.00	45.00	39.61	5.00	34.36	93.61	24.99	
120.16	4.00	1.00	1.00	45.00	40.34	15.00	36.89	81.57	23.42	
120.17	4.00	1.00	1.00	45.00	41.33	25.00	38.13	64.36	19.74	
120.18	4.00	1.00	1.00	45.00	42.78	35.00	41.03	38.85	12.60	
120.19	4.00	1.00	2.50	5.00	6.46	15.00	6.09	-24.60	-6.16	
120.20	4.00	1.00	2.50	5.00	8.47	25.00	7.66	-41.94	-17.39	
120.21	4.00	1.00	2.50	5.00	12.98	35.00	10.83	-121.20	-37.29	
120.22	4.00	1.00	2.50	5.00	17.68	45.00	13.76	-218.39	-72.10	
120.23	4.00	1.00	2.50	15.00	13.53	5.00	14.11	24.21	5.91	
120.24	4.00	1.00	2.50	15.00	17.13	25.00	16.26	-36.06	-11.00	
120.25	4.00	1.00	2.50	15.00	20.49	35.00	18.18	-95.26	-30.41	
120.26	4.00	1.00	2.50	15.00	25.94	45.00	21.33	-196.64	-64.26	
120.27	4.00	1.00	2.50	25.00	21.48	5.00	23.26	59.66	16.15	
120.28	4.00	1.00	2.50	25.00	22.88	15.00	23.96	35.87	16.47	
120.29	4.00	1.00	2.50	25.00	27.27	35.00	28.62	-56.75	-18.00	
120.30	4.00	1.00	2.50	25.00	33.59	45.00	29.29	-149.21	-51.77	
120.31	4.00	1.00	2.50	35.00	28.51	5.00	32.23	112.11	32.97	
120.32	4.00	1.00	2.50	35.00	29.85	15.00	32.78	89.04	27.61	
120.33	4.00	1.00	2.50	35.00	31.86	25.00	33.63	54.38	17.68	
120.34	4.00	1.00	2.50	35.00	39.98	45.00	37.32	-187.85	-51.30	
120.35	4.00	1.00	2.50	45.00	34.24	5.00	40.67	187.82	58.82	
120.36	4.00	1.00	2.50	45.00	35.52	15.00	41.14	165.91	53.95	
120.37	4.00	1.00	2.50	45.00	37.43	25.00	41.85	133.98	44.75	
120.38	4.00	1.00	2.50	45.00	40.36	35.00	43.00	81.63	28.26	
120.39	4.00	1.00	2.50	5.00	6.29	15.00	6.86	-21.46	-4.91	
120.40	4.00	1.00	2.50	5.00	8.15	25.00	7.53	-52.95	-13.82	
120.41	4.00	1.00	2.50	5.00	10.75	35.00	9.67	-101.43	-29.48	
120.42	4.00	1.00	2.50	5.00	15.42	45.00	12.98	-178.57	-56.44	
120.43	4.00	1.00	2.50	15.00	13.71	5.00	14.16	21.20	4.72	
120.44	4.00	1.00	2.50	15.00	16.82	25.00	16.18	-31.18	-8.74	
120.45	4.00	1.00	2.50	15.00	19.37	35.00	17.92	-79.14	-24.85	
120.46	4.00	1.00	2.50	15.00	23.93	45.00	20.68	-165.22	-50.35	
120.47	4.00	1.00	2.50	25.00	21.96	5.00	23.35	51.43	12.99	
120.48	4.00	1.00	2.50	25.00	23.19	15.00	24.02	30.52	8.36	
120.49	4.00	1.00	2.50	25.00	27.69	35.00	28.44	-46.99	-14.98	

Table P.2 (Cont) Simulated database

Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	ICA W/C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kWh	Mass transfer g/s
120.0	2.00	1.00	4.00	25.00	37.31	45.00	27.12	-100.46	-34.97
120.0	2.00	1.00	4.00	33.00	24.72	33.40	33.40	89.49	23.30
120.0	2.00	1.00	4.00	35.00	27.01	15.00	33.69	66.72	19.36
120.0	2.00	1.00	4.00	35.00	36.25	25.00	34.17	49.94	12.26
120.0	2.00	1.00	4.00	35.00	42.02	45.00	36.45	-62.67	-20.96
120.0	2.00	1.00	4.00	45.00	28.57	5.00	41.64	142.05	46.62
120.0	2.00	1.00	4.00	45.00	30.01	15.00	42.16	123.20	37.05
120.0	2.00	1.00	4.00	45.00	33.92	25.00	42.65	96.82	36.44
120.0	2.00	1.00	4.00	45.00	36.42	35.00	43.46	57.05	18.94
00.0	4.00	1.00	1.00	5.00	6.01	15.00	9.16	-17.09	-4.39
00.0	4.00	1.00	1.00	5.00	7.51	25.00	14.44	-42.93	-12.59
00.0	4.00	1.00	1.00	5.00	9.95	35.00	21.12	-83.49	-26.90
00.0	4.00	1.00	1.00	5.00	13.74	45.00	29.24	-149.47	-61.35
00.0	4.00	1.00	1.00	15.00	13.99	5.00	11.61	16.71	3.96
00.0	4.00	1.00	1.00	15.00	16.49	25.00	19.30	-25.29	-7.69
00.0	4.00	1.00	1.00	15.00	18.78	35.00	25.06	-65.52	-21.26
00.0	4.00	1.00	1.00	15.00	22.58	45.00	32.29	-124.01	-44.63
00.0	4.00	1.00	1.00	25.00	22.69	5.00	16.04	40.77	18.53
00.0	4.00	1.00	1.00	25.00	23.54	15.00	21.46	24.44	7.00
00.0	4.00	1.00	1.00	25.00	27.21	35.00	29.72	-38.38	-13.63
00.0	4.00	1.00	1.00	25.00	30.60	45.00	35.93	-100.28	-35.53
00.0	4.00	1.00	1.00	35.00	36.64	5.00	26.46	95.00	21.20
00.0	4.00	1.00	1.00	35.00	31.55	15.00	28.45	66.20	18.15
00.0	4.00	1.00	1.00	35.00	32.90	25.00	31.19	36.64	11.78
00.0	4.00	1.00	1.00	35.00	36.33	45.00	40.25	-58.59	-21.31
00.0	4.00	1.00	1.00	45.00	37.79	5.00	34.00	126.07	37.63
00.0	4.00	1.00	1.00	45.00	38.65	15.00	35.58	111.24	35.09
00.0	4.00	1.00	1.00	45.00	39.93	25.00	37.69	89.69	29.47
00.0	4.00	1.00	1.00	45.00	41.99	35.00	40.69	54.55	18.76
00.0	4.00	1.00	1.00	5.00	5.00	15.00	9.10	-14.98	-3.52
00.0	4.00	1.00	1.00	5.00	7.16	25.00	14.22	-36.73	-10.09
00.0	4.00	1.00	1.00	5.00	9.12	35.00	20.63	-70.11	-21.54
00.0	4.00	1.00	1.00	5.00	12.25	45.00	28.46	-122.75	-40.78
00.0	4.00	1.00	1.00	15.00	14.11	5.00	11.61	14.64	3.14
00.0	4.00	1.00	1.00	15.00	16.25	25.00	19.29	-21.45	-6.14
00.0	4.00	1.00	1.00	15.00	18.14	35.00	24.77	-54.23	-16.99
00.0	4.00	1.00	1.00	15.00	21.10	45.00	31.66	-105.80	-35.47
00.0	4.00	1.00	1.00	25.00	22.99	5.00	18.82	35.16	8.34
00.0	4.00	1.00	1.00	25.00	23.74	15.00	21.50	26.04	5.58
00.0	4.00	1.00	1.00	25.00	26.06	35.00	29.59	-31.81	-10.36
00.0	4.00	1.00	1.00	25.00	29.69	45.00	35.32	-81.05	-28.04
00.0	4.00	1.00	1.00	35.00	31.23	5.00	26.47	64.69	16.79
00.0	4.00	1.00	1.00	35.00	32.05	15.00	28.54	56.76	14.45
00.0	4.00	1.00	1.00	35.00	33.23	25.00	31.29	30.63	9.41
00.0	4.00	1.00	1.00	35.00	37.72	45.00	40.00	-47.92	-16.97
00.0	4.00	1.00	1.00	45.00	38.87	5.00	34.28	106.75	38.64
00.0	4.00	1.00	1.00	45.00	39.65	15.00	35.65	83.57	28.13
00.0	4.00	1.00	1.00	45.00	40.75	25.00	37.96	74.37	23.66
00.0	4.00	1.00	1.00	45.00	42.42	35.00	40.99	45.19	5.00
120.0	4.00	1.00	1.00	5.00	5.00	15.00	9.06	-13.45	-2.93

Table P.2 (Cont) Simulated database

	Air pressure drop Pa	Water flow rate kg/s	Air mass flow rate (dry) kg/s	h <sub>2</sub> O W/C	Inlet water temperature °C	Outlet water temperature °C	Inlet wet-bulb temperature °C	Outlet wet-bulb temperature °C	Duty kW	Mass transfer kg/s
88.81	2.88	1.88	4.88	5.88	12.72	25.88	6.84	-65.88	-18.28	
88.81	2.88	1.88	4.88	5.88	19.93	35.88	7.14	-128.54	-39.85	
88.81	2.88	1.88	4.88	5.88	31.39	45.88	9.36	-221.83	-75.32	
88.81	2.88	1.88	4.88	5.88	11.94	5.88	14.57	25.76	6.31	
88.81	2.88	1.88	4.88	5.88	19.51	25.88	15.61	-39.87	-11.59	
88.81	2.88	1.88	4.88	5.88	26.57	35.88	16.83	-189.28	-31.84	
88.81	2.88	1.88	4.88	5.88	37.58	45.88	19.29	-199.87	-66.98	
88.81	2.88	1.88	4.88	5.88	17.43	5.88	23.88	62.59	17.88	
88.81	2.88	1.88	4.88	5.88	28.59	15.88	29.29	37.53	18.98	
88.81	2.88	1.88	4.88	5.88	31.89	33.88	28.25	-56.78	-19.47	
88.81	2.88	1.88	4.88	5.88	41.82	45.88	29.26	-149.76	-51.91	
88.81	2.88	1.88	4.88	5.88	21.88	5.88	32.51	114.19	33.56	
88.81	2.88	1.88	4.88	5.88	24.82	15.88	32.94	98.23	28.91	
88.81	2.88	1.88	4.88	5.88	28.71	25.88	33.63	54.42	17.89	
88.81	2.88	1.88	4.88	5.88	44.87	45.88	38.84	-88.99	-28.91	
88.81	2.88	1.88	4.88	5.88	24.88	5.88	48.88	188.58	56.28	
88.81	2.88	1.88	4.88	5.88	25.88	15.88	48.48	157.78	51.88	
88.81	2.88	1.88	4.88	5.88	38.79	25.88	41.87	124.86	41.59	
88.81	2.88	1.88	4.88	5.88	36.88	35.88	42.31	73.22	25.58	
188.81	2.88	1.88	4.88	5.88	7.73	15.88	5.48	-22.79	-5.17	
188.81	2.88	1.88	4.88	5.88	11.84	25.88	5.94	-56.27	-14.52	
188.81	2.88	1.88	4.88	5.88	17.57	35.88	8.88	-187.74	-38.85	
188.81	2.88	1.88	4.88	5.88	26.83	45.88	8.39	-189.58	-58.96	
188.81	2.88	1.88	4.88	5.88	12.38	5.88	14.61	22.51	5.84	
188.81	2.88	1.88	4.88	5.88	18.84	25.88	15.51	-33.14	-9.23	
188.81	2.88	1.88	4.88	5.88	24.71	35.88	16.44	-93.58	-25.26	
188.81	2.88	1.88	4.88	5.88	33.67	45.88	18.84	-164.84	-62.84	
188.81	2.88	1.88	4.88	5.88	18.61	5.88	24.89	54.39	13.76	
188.81	2.88	1.88	4.88	5.88	21.21	15.88	24.42	32.14	8.83	
188.81	2.88	1.88	4.88	5.88	38.63	35.88	25.91	-49.33	-15.64	
188.81	2.88	1.88	4.88	5.88	39.23	45.88	27.74	-126.26	-42.13	
188.81	2.88	1.88	4.88	5.88	23.45	5.88	35.86	89.12	27.57	
188.81	2.88	1.88	4.88	5.88	25.98	15.88	35.41	77.89	22.75	
188.81	2.88	1.88	4.88	5.88	29.61	25.88	33.98	46.67	14.55	
188.81	2.88	1.88	4.88	5.88	43.81	45.88	37.84	-171.89	-24.52	
188.81	2.88	1.88	4.88	5.88	26.65	5.88	41.14	-58.74	-47.37	
188.81	2.88	1.88	4.88	5.88	29.88	15.88	41.48	138.27	43.12	
188.81	2.88	1.88	4.88	5.88	32.54	25.88	42.84	188.84	35.32	
188.81	2.88	1.88	4.88	5.88	37.42	35.88	43.82	64.89	21.82	
128.81	2.88	1.88	4.88	5.88	7.48	15.88	5.39	-28.58	-4.58	
128.81	2.88	1.88	4.88	5.88	16.93	25.88	5.88	-49.98	-12.83	
128.81	2.88	1.88	4.88	5.88	15.99	35.88	6.58	-94.17	-25.58	
128.81	2.88	1.88	4.88	5.88	23.84	45.88	7.98	-232.56	-48.39	
128.81	2.88	1.88	4.88	5.88	12.56	5.88	14.65	28.41	4.28	
128.81	2.88	1.88	4.88	5.88	18.39	25.88	15.45	-27.19	-7.88	
128.81	2.88	1.88	4.88	5.88	23.43	35.88	16.28	-72.78	-28.92	
128.81	2.88	1.88	4.88	5.88	31.18	45.88	17.58	-148.34	-43.67	
128.81	2.88	1.88	4.88	5.88	19.27	5.88	24.21	48.75	11.58	
128.81	2.88	1.88	4.88	5.88	21.84	15.88	24.58	28.91	7.39	
128.81	2.88	1.88	4.88	5.88	29.98	35.88	25.74	-82.77	-13.81	

Table P.2 (Cont) Simulated database

## APPENDIX Q Determination of the relationship

$$L = f(Z, N^*)$$

The appropriate value of  $c_{aw}^*$  must lie between its value at the water inlet temperature and that at the air inlet wet-bulb temperature. This may be described by:

$$c_{aw}^* = L c_{awI}^* + (1 - L) c_{aaf}^* \quad (Q.1)$$

where

$$L = 0 \text{ to } 1$$

The term L will have a value between 0 and 1 depending on the ratio of thermal capacities and the value of the design characteristic, thus:

$$L = f(m_w/m_a, N^*) \quad (Q.2)$$

Based on the selected universal values of:

$$\begin{aligned} [(\alpha/\beta) c_{avaf}^*] &= 1,00 \text{ for all applications} \\ (\alpha/\gamma)_i &= 1,00 \text{ for water cooling} \\ &= 1,05 \text{ for air cooling,} \end{aligned}$$

a set of values of  $c_{aw}^*$  was calculated for each test and values of L for each test was then determined. Note, this included the large database of simulated tests which were calculated in order to supplement the experimental database.

Based on this information a curve fitting exercise was undertaken, with the following result:

$$L = (m_w/m_a)^{1.3} / [ 0.5N^{0.5} + (m_w/m_a)^{1.3} ] \quad (Q.3)$$

## REFERENCES

1. Bluhm, S.J., Ramsden, R. and Ferguson, D. Heat exchangers for cooling air in mines, Journal of South African Mechanical Engineer, vol. 34, Oct. 1984, pp. 358-366.
2. Ramsden, R. and Bluhm, S.J. Air cooling equipment used in South African gold mines, Third International Mine Ventilation Congress, Harrogate, England, June 1984.
3. Ramsden, R. and Bluhm, S.J. Control of the underground thermal environment in South African gold mines, Journal of South African Refrigeration and Air Conditioning, July 1988, pp. 23-32.
4. Bluhm, S.J. and Whillier, A. The design of spray chambers for bulk cooling of air in mines, Journal of South African Institute of Mining and Metallurgy, vol. 79, no. 1, Aug. 1978, pp. 3-11.
5. Bluhm, S.J. Predicting performance of spray chambers for cooling air, Journal of Heating, Air Conditioning and Refrigeration, vol. 13, no. 2, Nov. 1980, pp. 27-39.
6. Bluhm, S.J. and Lancaster, G.J. Optimum use of daily changes in wet-bulb temperature in the operation of surface precooling towers, Journal of Mine Ventilation Society of South Africa, vol. 40, May 1987, pp. 64-70.

## REFERENCES

7. Gebler, W.F., Bluhm, S.J., Ramsden, R., Feio, L. The design and evaluation of a large direct-contact ice-air cooler for Vaal Reefs gold mine, Proceedings of the Fourth International Mine Ventilation Congress, Australasian Institute of Mining and Metallurgy, Brisbane, July 1988.
8. Baker, D.R. and Hart, L.T. Cooling tower performance, Chemical Engineering, vol. 59, Dec. 1952, pp. 196-199.
9. BRITISH STANDARDS. Specification for cooling towers. BS 4485, Part 3, 1977.
10. ASHRAE, Handbook of Fundamentals, 1989.
11. Stoeker, W.F. and Jones, W.F. Refrigeration and air conditioning, 2nd ed. McGraw-Hill, 1958.
12. Merkel, F. 'Verdunstungskühling, V.D.I. Forschungsarbeiten, no. 275, Berlin, 1925.
13. Sutherland, J.W. Analysis of mechanical - draught counterflow air/water cooling towers, Transactions ASME, vol. 105, Aug. 1983, pp. 576-583.
14. Majumdar, A.K., Singhal, A.K. and Spalding, D.B. Numerical modeling of wet cooling towers - Part 1 : Mathematical and physical models, Transactions ASME, vol. 105, Nov. 1983, pp. 728-743.
15. Webb, R.L. and Villacres, A. Algorithms for performance simulation of cooling towers, evaporative condensers and fluid coolers, Transactions ASHRAE, vol. 90, 1984.

## REFERENCES

16. Webb, R.L. A unified theoretical treatment for thermal analysis of cooling towers, evaporative condensers and fluid coolers, Transactions ASHRAE, vol.90, 1984.
17. Whillier, A. An improved analysis of counterflow cooling tower performance, Journal of South African Mechanical Engineer, vol. 18, no. 9, April 1969, pp. 226-232.
18. Whillier, A. Predicting the performance of forced-draught cooling towers, Journal of Mine Ventilation Society of South Africa, vol. 30, Jan. 1977, pp. 2-25.
19. Whillier, A. A fresh look at the performance of cooling towers, Transactions ASHRAE, vol. 82, 1976, pp. 269-282.
20. Bluhm, S.J. Performance of direct contact heat exchangers, Journal of Mine Ventilation Society of South Africa, vol. 34, Aug. 1981, pp. 155-160.
21. Threlkeld, James L. Thermal Environmental Engineering, 2nd ed. New Jersey: Prentice-Hall, Inc., 1962.
22. Bluhm, S.J. Heat transfer characteristics of direct-contact crossflow spray chambers, MSc Dissertation, University of the Witwatersrand, Johannesburg, South Africa, 1981.
23. Jaber, H. and Webb, R.L. Design of cooling towers by the effectiveness - NTU method, Journal of Heat Transfer, vol. III, Nov. 1989, pp. 837-843.

## REFERENCES

24. Baker, D.R. and Shryock, H.A. A comprehensive approach to the analysis of cooling tower performance, Journal of Heat Transfer, vol. 83, 1961, pp. 339-350.
25. Berman, L.D. Evaporative cooling of circulating water, 2nd ed. London: Pergamon Press, 1961.
26. Perry, R.H. and Chilton, C.H. Chemical Engineers' Handbook, 5th ed. McGraw-Hill, 1973.
27. Kern, D.Q. Process Heat Transfer, New York: McGraw-Hill, 1950.
28. Mayhew, Y.R. and Rogers, G.F.C. Thermodynamic and Transport Properties of Fluids, 2nd ed. Oxford: Basil Blackwell, 1971.
29. Burruss, E. ed. Environmental Engineering in South African Mines, Mine Ventilation Society of South Africa, 1982.
30. Gilliland, E.R. Diffusion coefficients in gaseous systems. Industrial and Engineering Chemistry, vol. 26, no. 6, June, 1934.
31. Carrier, W.H. Rational psychrometric formulae, Transactions ASME, vol. 33, 1911, pp. 1309.
32. Fuller, E.N., Ensley, K., Giddings, J.C. Journal of Physical Chemistry, vol. 75. 1969.
33. Reid, R.C. and Sherwood, R.L. The properties of gases and liquids, New York: McGraw-Hill, 1958.

## REFERENCES

34. Mason, E. A. and Monchick, L. Heat conductivity of polyatomic and polar gases, J. Chem. Phys. vol 36, 1962, pp 1622.
35. Mason, E. A. and Monchick, L. Survey of the equation of state and transport properties of moist gases. Humidity and Moisture, vol. 3, Fundamentals and Standards, New York: Reinhold Publishing Corp, 1965, pp. 257.
36. Sherwood, T. K. and Pigford, R. L. Absorption and Extraction, New York: McGraw-Hill, 1958.
37. Sutherland. Philosophical Magazine, vol. 38, 1894, pp. 1.
38. Spalding, D. B. Thesis in chemical engineering, (S.B.) Dissertation, MIT, 1946.
39. Jakob, M. Heat transfer, vol. 1, New York: John Wiley and Sons, 1949.
40. Goff, J. A. and Gratch, S. Thermodynamic properties of moist air, Transaction ASHVE, vol. 51, 1945, pp. 125.
41. Goff, J. A. Standardization of thermodynamic properties of moist air, Transaction ASHVE, vol. 55, 1949, pp 459.
42. Barenbrug, A.W.T. Psychrometry and psychrometric charts, 3rd ed. Johannesburg: Chamber of Mines of South Africa, 1974.

## REFERENCES

43. Kennan, J.H., Keyes, F.G., Hill, P.G. and Moore, J.G. Steam Tables, Thermodynamic Properties of Water, Including Vapor, Liquid, and Solid Phases, New York: John Wiley and Sons, 1960.
44. Keenan, J.H. and Keyes, F.G., Thermodynamic Properties of Steam, New York: John Wiley and Sons, 1936.
45. Whillier, A. Psychrometric charts for all barometric pressures, Journal of Mine Ventilation Society of South Africa, vol. 24, no. 9, Sept. 1971, pp. 138-143.
46. Whillier, A. Calculation of heat exchange between air and wet surfaces, Journal of South African Institute of Mining and Metallurgy, vol. 78, no. 8, March 1967, pp. 3-11.
47. McKelvey, K.K. and Brooke, M. The Industrial Cooling Tower, Amsterdam: Elsevier Publishing Co., 1959.
48. Wimmerstedt, R. Berechnung von gegenstrom kuhltermen bei hoher wasser eintrittstemperatur. Klima-Technit. Heft 7-8, 1976.
49. McAdam, W.H. Heat Transmission, 3rd ed. New York: McGraw Hill, 1954.
50. Eckert, E.R.G. and Drake, R.M. Heat and Mass Transfer, 2nd ed. Tokyo: McGraw Hill, 1959.

## REFERENCES

51. Kays, W.M. and London, A.L. Compact Heat Exchangers, 2nd ed. New York: McGraw-Hill, 1964.
52. Bayley, F.J., Owen; J.M. and Turner, A.B. Heat transfer, London: Thomas Nelson and Sons, 1972.
53. Deissler, R.G. Analysis of turbulent heat transfer, mass transfer and friction in smooth tubes at high Prandtl and Schmidt Numbers, NACA Report 1210, 1955.
54. Evans, H.L. Mass transfer through laminar boundary layers - further similar solutions to the b-equation for the case of  $B = 0$ , International Journal of Heat Mass Transfer, vol. 5, 1962, pp. 33-57.
55. Nusselt, W. Die oberflächen kondensation des wasserdampfes, Z.VDI, 1916, 60, 541, 569.
56. Evans, H.L. Mass transfer through laminar boundary layer. Methods of evaluating the wall gradient ( $b_0/B$ ) for similar solutions; some new values for zero main stream pressure gradient, International Journal of Heat and Mass Transfer, vol. 3, 1961, pp.321-339.
57. Gebler, W.F. and Ramsden, R. Guidelines for performance testing of surface bulk air coolers. Journal of the Mine Ventilation Society of South Africa, vol. 40, no. 5, May 1987, pp. 57-84.
58. Nottage, H.B. Merkel's diagram as a performance correlation for air-water evaporative cooling systems. Transactions ASHVE, Paper no. 1190, 1941.

## REFERENCES

59. Cooling Tower Institute. Cooling Tower Institute Performance Curves. The Cooling Tower Institute, Houston: 1967.
60. Chicholm, D. Heat Exchanger Design Handbook, Section 2.6.7, Fogging. International Centre for heat and mass transfer. Dusseldorf: Hemisphere Publishing Corp, 1983.
61. Coughanowr, D.R. and Stensholt, E.O. Analogue computer method for designing a cooler condenser with fog formation, Ind. Eng. Chem., vol. 3, no. 4, 1964, pp. 369-373.
62. Bras, G.H.P. Chemical engineering aspects of fog formation in cooler condensers, Ind. Eng. Chem., vol. 31, no. 360, 1955, pp. 22-31.
63. Colburn, A.P. and Edison, A.G. Prevention of fog in cooler condensers, Ind. Eng. Chem., vol. 33, no. 4, 1941, pp. 457-458.
64. BRITISH STANDARD. Methods of measurement of fluid flow in closed conduits. BS. 1042, Section 1.1, 1981.
65. Andrews, P.J. A manufacturer's viewpoint on direct contact air to water heat exchanger. Journal of the Mine Ventilation Society of South Africa, vol. 38, no. 7, July 1985, pp. 73-78.
66. Maxwell. Philosophical Magazine, vol. 35, 1868, pp. 185.

## REFERENCES

67. Spalding, D.B. Convective Mass Transfer, An Introduction, London: Edward Arnold, 1963.
68. Spalding, D.B. A standard formulation of the steady convective mass transfer problem. Int. J. Heat and Mass Transfer, vol. 1, 1960, pp. 192-207.
69. Skelland, A.H.P. Diffusional Mass Transfer, New York: John Wiley and Sons, 1974.
70. Nahavandi, A.N., Kershah, R.M., Serico, B.J. Effect of evaporation losses in the analysis of counterflow cooling towers. Nuclear Eng. Design, vol. 32, no. 1, 1975, pp. 29.
71. Kays, W.M. Convective Heat and Mass Transfer, New York: McGraw-Hill, 1966.
72. Hottel, H.C. and Sarafim, A.F. Radiative transfer, New York: McGraw Book Co., 1967.
73. Holman, J.P. Heat Transfer, 4th ed. Kogakusha Ltd: McGraw-Hill, 1976.
74. Carrier, W.H. The contact-mixture analogy applied to heat transfer with mixtures of air and water vapour, Transactions ASME, vol. 59, 1937, pp. 49-53.
75. Traybal, R.E. Mass transfer operations, 3rd ed., Tokyo: McGraw-Hill, 1981.
76. Lewis, W.K. The evaporation of a liquid into a gas, Transactions ASME, vol. 44, 1922, pp. 455.

## REFERENCES

77. Chilton, T.H. and Colburn, A.P. Mass transfer (absorption) coefficients. Prediction from data on heat transfer and fluid friction, Ind. Eng. Chem., vol. 26, Nov. 1935, pp. 1183-1187.
78. Reynolds, O. On the extent and action of the heat surface for steam boilers. Proc. Manchester Lit. Phil. Society, 1874, (reprinted in Scientific Papers of Osborne Reynolds, vol. 2, Cambridge, London).
79. Fletcher, D.F., Maskill, S.J. and Patrick, M.A. Theoretical investigation of the Chilton-Colburn analogy - using a modified form of the Van Driest eddy viscosity hypothesis. Transaction Inst. Chem. E., vol. 60, 1982, pp. 122-125.
80. MICKLEY, H.S. Heat, mass and momentum transfer for flow over a flat plate with blowing and suction. NACA TN 3208. 1954.
81. Spalding, D.B. The combustion of liquid fuels. PhD Thesis, Mechanical Engineering Department, Cambridge University. 1951.
82. Ganic, E.N. and Mastanaiah, H. Hydrodynamics and heat transfer in falling film flow, in: Low Reynolds Number Flow Heat Exchangers, Washington : Hemisphere Publishing Co., 1983, pp. 487-526.

## REFERENCES

83. Boelter, L.M.K. Cooling tower performance studies. Transaction ASHVE. Semi-annual meeting, Mackinac Island, Michigan: July, 1939.
84. ASHRAE STANDARD. (41. 5-75). Standard measurement guide; engineering analysis of experimental data. 1976.
85. Zemansky, M.W., Dittman, R.H. Heat and thermodynamics, 6th ed. Tokyo: McGraw-Hill, 1981.
86. Ramsden, R. The temperature rise of chilled water flowing through pipe, Journal of Mine Ventilation Society of South Africa, vol. 36, no. 9, Sept. 1983, pp. 85-93.
87. Dowdy, P.E., Reid, R.L. and Handy, E.T. Experimental determination of heat- and mass- transfer coefficients in aspen pads. ASHRAE Transactions. Paper no. 2978.
88. Yun-Yu Lin, Hesketh, H.E. Simultaneous heat and mass transfer in a catenary cooling tower. Journal of Engineering for Gas turbines and Power, vol. 109, July 1987, pp. 245.
89. ASHRAE, Equipment Handbook, 1988.
90. Erens, P.J. Performance predictions on mechanical draught towers. S.A. Refrigeration and Airconditioning, July 1986, pp. 49.

## REFERENCES

91. Nottage, H.B. and Boelter, L.M.K. Dynamic and thermal behaviour of water drops in evaporative cooling processes. American Society of Heating and Ventilation Engineers. Research Report No. 1146, 1940.
92. Lowe, H.J. and Christie, D.G. Heat transfer and pressure drop data on cooling tower packings and model studies of the resistance of natural draught towers to airflow. International Heat Transfer Conference, Boulder, Colorado, 1961.
93. Lichtenstein, J. Performance and selection of mechanical draft cooling towers, Transactions ASME, Oct. 1943, pp. 779.
94. Yadijaroglu, G. Investigation of the accuracy of the Merkel equation for evaporative cooling tower calculations. ASME Paper 74-HT-59, July 1974.
95. Lefevre, M.R. Eliminating the Merkel theory approximations - can it replace the empirical temperature correction factor. Technical Paper no. TP-84-18. Cooling Tower Institute Annual Meeting. Houston: Feb. 1984.
96. Amano, R.S., Bacherlee, A., Smith, R.J., and Niess, T.G. Turbulent heat transfer in corrugated wall channels with or without fins, Transactions ASME, vol. 109, Feb. 1987, pp. 62.

## REFERENCES

97. London, A.L., Mason, W.F. and Boelter, L.M.K. Performance characteristics of a mechanically induced draft, counterflow, packed cooling tower. Transactions ASME, vol. 62, pp. 41-50.
98. Kelly, N.W. Kelly's Handbook of Crossflow Cooling Tower Performance, Neil W Kelly & Associates, Kansas City, MO: 1976.
99. Moffatt, R.J. The periodic flow cooling tower : a design analysis. Technical Report No. 62, Department Mechanical Engineering, Stanford University, CA: 1966.
100. Keyes, R.E. Methods of calculation for natural draft cooling towers, 13th National Heat Transfer Conference, Denver, CO: Aug, 1972.
101. Zivi, S.M. and Brand, B.B. Analysis of the crossflow cooling tower, Refrigeration Engineering, vol. 64, no. 8, 1956, pp. 31-34.
102. Lefevre, M.R. Influence of air and water temperature on fill characteristics curve, Technical Paper no. TP-85-8. Cooling Tower Institute Annual heating, New Orleans: Jan. 1985.
103. Schultz, T., Erens, P.J. Measurement of cooling tower fill material performance at low temperatures. ASHRAE-FRIGAIR 90 Conference, Pretoria: April 1990.

## REFERENCES

104. Benton, D.J. and Waldrop, W.Z. Computer simulation of transport phenomena in evaporative cooling towers. Transactions ASME, vol. 110, April 1988, pp. 190.

105. Kametani, S, Fujita, T and Tezuka, S. Enthalpy - transfer coefficients in a mechanical draft counterflow cooling heating tower. 17th International Congress of Refrigeration, Vienna: August, 1987.

106. Baker, D. Cooling tower performance. New York: Chemical Publishing Co., 1984.

## BIBLIOGRAPHY

1. Leidenfrost, W. and Korenic, B. Evaporative cooling and heat transfer augmentation related to reduced condenser temperatures, Journal of Heat Transfer Engineering, Vol. 3, nos 3-4, pp. 38-59, 1982.
2. Leidenfrost, W. and Korenic, B. Analysis of evaporative cooling and enhancement of condenser efficiency and of coefficient of performance, Warme-Und Stoffubertraquag, Vol 12, pp 5-23, 1979.
3. Bosnjakovic, F. Technical Thermodynamics, (Translated by Blackshear, P.L.), Holt, Rinehart and Winston, New York, pp 1-80, 1965.
4. Poppe, M. and Rogener, H. Berechnung Von Rückkühlwerken. VDI - Warmteatlas 4, Auflage, 1984.
5. Bourillot, C. TEFERI, Numerical model for calculating the performance of an evaporative cooling tower. EPRI. Special Report CS-3212-SR, August 1983.
6. Kassim, A.N. Ein beitrag zum warme-und stoffübergang im nasskühlturm bei gegenstrom. Dr. Ing. Thesis, University of Stuttgart, 1979.
7. Parker, R.O. and Treybal, R.E. The heat and mass transfer characteristics of evaporative coolers. Chemical Engineering Progress symposium Series, Vol 57, pp 138-149, 1961.
8. Brens, P.J. and Freyer, A.A. An improved procedure for calculating the performance of evaporative closed circuit coolers. AIChE Symposium Series - Heat Transfer, Houston, Vol 84, 1988.

**Author: Bluhm Steven John.**

**Name of thesis: Thermal Performance Of Direct-contact Water-air Heat Exchangers.**

***PUBLISHER:***

University of the Witwatersrand, Johannesburg

©2015

***LEGALNOTICES:***

**Copyright Notice:** All materials on the University of the Witwatersrand, Johannesburg Library website are protected by South African copyright law and may not be distributed, transmitted, displayed or otherwise published in any format, without the prior written permission of the copyright owner.

**Disclaimer and Terms of Use:** Provided that you maintain all copyright and other notices contained therein, you may download material (one machine readable copy and one print copy per page) for your personal and/or educational non-commercial use only.

The University of the Witwatersrand, Johannesburg, is not responsible for any errors or omissions and excludes any and all liability for any errors in or omissions from the information on the Library website.